

Date	Suspended solids	Dissolved solids	Oil and grease	Copper	Pb	Sn	Zn	Al	Mercury	Arsenic	Ni	Nitrogen	pH max	pH min	Comments
31.10.2022	6	733	1	0.0054	0.0003	0.0015	0.007	0.065	0.00001	0.0027	0.001	0.41	8	8	
Limit	50	1200	10	0.25	0.1	0.1	0.5	1.5	0.075	0.1	0.5	1.5	9	6	

0.0054 0.0003 0.0015 0.007 0.00001 0.0027 0.001 0.41

Real Alloy UK Ltd EP3935UC
Water Results October 2022