

Schedule 1 - Notification of abnormal emissions

This page outlines the information that the Operator must provide to satisfy conditions 5.1.1 and 5.1.2 of this Permit.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the PPC Regulations.

Part A

Permit Number	BX7282IS
Name of Operator	AB-INBEV
Location of Installation	MAGOR
Location of the emission	BTS
Time and date of the emission	8.45PM 9TH SEPTEMBER

Substance(s) emitted	Media	Best estimate of the quantity or the rate of emission	Time during which the emission took place
PH OF 9.08	WATER	2.46 M ³	08.45

Measures taken, or intended to be taken, to stop the emission	CHECK PROBE CLEANING FREQUENCY
---	--------------------------------

Part B

Any more accurate information on the matters for notification under Part A.	SPIKE NOTICED AT OUTLET. PROBE CLEANED.
Measures taken, or intended to be taken, to prevent a recurrence of the incident	RECALIBRATED THE PROBE (95% ACCURACY) CLEANED PUMP PIT.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission	REGULAR INSPECTIONS OF PIT CONDITION.
The dates of any unauthorised emissions from the installation in the preceding 24 months.	19TH JULY 2017

Name*	CARL ROGERS
Post	ENVIRONMENT AND SAFETY MANAGER
Signature	
Date	28/9/18.
* authorised to sign on behalf of Interbrew UK Ltd	