

## Schedule 1 - Notification of abnormal emissions

This page outlines the information that the Operator must provide to satisfy conditions 5.1.1 and 5.1.2 of this Permit.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the PPC Regulations.

### Part A


Permit Number	AP3433ES
Name of Operator	Kepak Group Ltd
Location of Installation	Merthyr Tydfil
Location of the emission	HT4 & 1&3 Plantroom E.
Time and date of the emission	05/08/2018

Substance(s) emitted	Media	Best estimate of the quantity or the rate of emission	Time during which the emission took place
FGAS	R404A	383.44KGS	05/08/2018

Measures taken, or intended to be taken, to stop the emission	Continuation of undertaking of leak detection work and planned maintenance of refrigeration units.
---	--

### Part B

Any more accurate information on the matters for notification under Part A.	Pack HT4, topped up after previous repairs, Tunnels 1&3 Plantroom- Leak on oil rectification vessel isolated.
Measures taken, or intended to be taken, to prevent a recurrence of the incident	Continuation of undertaking of leak detection work and planned maintenance of refrigeration units.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission	
The dates of any unauthorised emissions from the installation in the preceding 24 months.	<p>29/07/2018- Emission to Air refrigerant R448a</p> <p>26/07/18- S1 - Emission exceedance Hydrocarbons</p> <p>19/07/18- S1 - Emission exceedance pH</p> <p>01/05/18- Emission to Air refrigerant R448a</p> <p>03/05/18- S1 - Emission exceedance pH</p> <p>17/05/18- S1 - Emission exceedance Hydrocarbons</p> <p>02/02/18 – W1 Emission of Mineral oil and hydrocarbon and suspended solids</p> <p>23/09/17 – Contractor HGV collision resulting in fuel spill</p> <p>13/04/17 – W1 Emission of Mineral oil and hydrocarbon</p> <p>30/03/17 – S1 Emission of Mineral oil and hydrocarbon</p> <p>02/03/17 – W1 Emission of Mineral oil and hydrocarbon</p> <p>06/06/16 – Refrigerant leak from crack pipe in system MT3</p> <p>02/06/16 – W2 Emission hydrocarbon</p>

Name*	Matt Dight
Post	Environmental Manager
Signature	
Date	19/10/2018

\* authorised to sign on behalf of 2 Sisters Red Meat Ltd