

 Navigator	Draining of Lagoon	Document Number NTW-OPS-PROC-0027
Document Owner Adam Gibson	Applies to: Navigator Terminals Windmill	Issue Number 9

Appendix 1

Site Name: Navigator Terminals Windmill Ltd

Permit Number: KP3734SH

Parameter	Analytical method	Value recorded	Permit limits	Within permit limits? (Y/N)
pH	Standard glass probe [Dow procedure CTM 0007]	9	6 > pH >10	YES
Visible oil/ grease (Appearance)	Visual examination [CTM 0176]	PASS	Must be Y / pass on appearance	YES
Total Organic Carbon	GC and FID [Dow procedure CTM 1144]	2.0	Must be less than 10ppm (10 mg/l)	YES

Date: 21/10/22

Results reviewed and acceptable to discharge? (Y/N): YES

(if not please follow step 6 onwards in procedure NTW-OPS-PROC-0027)

Quantity to discharge (approx.): 950mm

Name: ADAM GIBSON

Signature



: