

RELEASES TO AIR

QUARTERLY RETURN



CUMULATIVE ROLLING MALFUNCTION AND BREAKDOWN HOURS (12 MONTH PERIOD)^(a)

Operator: RWE Generation UK Form: IED BD1
 Location: Aberthaw Power Station Version/date: V.10.9 Dec 2015
 Permit/Variation Number: EPR/RP3133LD

Year: 2018 LCP: LCP 283	SO ₂		NO _x		Dust	
Month ^(b)	Malfunction (hours)	Breakdown (hours)	Malfunction (hours)	Breakdown (hours)	Malfunction (hours)	Breakdown (hours)
Oct 2017	0	0	0	0	0	0
Nov 2017	0	0	0	0	0	0
Dec 2017	0	0	0	0	0	0
Jan 2018	0	0	0	0	0	0
Feb 2018	0	0	0	0	0	0
Mar 2018	0	0	0	0	0	0
Apr 2018	0	0	0	0	0	0
May 2018	0	0	0	0	0	0
Jun 2018	0	0	0	0	0	0
Jul 2018	0	0	0	0	0	0
Aug 2018	0	0	0	0	0	0
Sep 2018	0	0	0	0	0	1
Annual cap (hours)	120	120	120	120	120	120

NOTES:

- (a) Cumulative rolling malfunction and breakdown hours (12 month period) updated monthly
- (b) Insert the relevant months for the preceding 12 month period, e.g., starting with March 2016
- (c) Gas turbines with CO abatement only (columns may be deleted)

Signed on behalf of the Operator by: *R.T. Powell*

Date of return: 04 October 2018