

REGISTER OF CONDITIONS

AND OTHER TERMS

IMPOSED UNDER SECTION 7 OF THE RIVERS (PREVENTION OF POLLUTION) ACT, 1951

(AS APPLIED BY THE CLEAN RIVERS (ESTUARIES AND TIDAL WATERS) ACT, 1960)

AND THE RIVERS (PREVENTION OF POLLUTION) ACT, 1961.

Bc 0005201 / RW 2300301

File Ref;? GS:1820(g) No. 680

CAT. No. R.B.12 SHAW & SONS LTD., FETTER LANE, E.C.4.

DATE ON WHICH CONDITION CAME INTO FORCE AND PERIOD OF EFFECT	FULL ADDRESS OR OTHER SUFFICIENT DESCRIPTION OF LAND OR PREMISES TO WHICH THE TERM OR CONDITION RELATES	
24th November, 1966 <i>Amended 24.1.67</i>	<u>Llwchwr Urban District Council</u> Discharge from S.O.C.No.7.	
USE OF NEW OR ALTERED OUTLET	DISCHARGE OF TRADE OR SEWAGE EFFLUENT	
<p>CONDITIONS IMPOSED WITH RESPECT TO:-</p> <p>(i) PRECISE LOCATION OF OUTLET</p> <p>Outlet to be located on right bank of Afon Lliw. Map South Wales 2½" O.S. Sheet SS/59 grid reference 5720 9745.</p> <p>(ii) CONSTRUCTION OF OUTLET (OTHER THAN CONDITIONS TO BE SATISFIED BEFORE OUTLET IS BROUGHT INTO USE)</p> <p>18" diameter concrete pipe and to be accessible for sampling at all times.</p> <p>(iii) USE OF OUTLET</p> <p>restricted to storm sewage</p> <p>(iv) USE OF ANY OTHER OUTLET FOR TRADE OR SEWAGE EFFLUENT FROM THE SAME LAND OR PREMISES</p>	<p>CONDITIONS IMPOSED WITH RESPECT TO:-</p> <p>(i) NATURE AND COMPOSITION OF DISCHARGE</p> <p>pH value not less than 6 or more than 8.5 Suspended solids not more than 50 p.p.m. <i>(with decrease to 25 p.p.m.)</i></p> <p>(ii) TEMPERATURE OF DISCHARGE</p> <p>not to exceed 21°C.</p> <p>(iii) VOLUME OR RATE OF DISCHARGE OF EFFLUENT FROM LAND OR PREMISES</p> <p>to operate for flows in excess of 22.7 c.f.m. for S.O.C. No.7 and 431.8 for Storm Tanks.</p> <p>* (iv) PROVISION OF FACILITIES FOR TAKING SAMPLES</p> <p>(v) DATE OF EXPIRATION OF PERIOD SPECIFIED UNDER S-5(2) OF 1961 ACT</p> <p>30th November, 1968.</p>	
REMARKS-	REMARKS-	

* IF DISCHARGE NOT CONTROLLED UNDER S.7 OF 1951 ACT

