

Company Secretary and/or Director  
Viridor Trident Park Limited  
Viridor House  
Priory Bridge Road  
Taunton  
TA1 1AP

**Our ref: EPR/LP3030XA  
Your ref: EPR/LP3030XA**

**Date: 21/12/2022**

Dear Sir/Madam,

**Emission monitoring agreement**

**Permit reference: EPR/LP3030XA**

**Operator: Viridor Trident Park Limited**

**Facility: Cardiff Energy Recovery Facility, Trident Park, Glass Avenue, Ocean Way,  
Cardiff, CF24 5EN**

In accordance with permit condition 3.6.1 and Schedule 3(b) Table S3.1 we confirm the following change to the monitoring requirements, which will remain in force until such time as we confirm otherwise in writing:

For monitoring specified in Schedule 3(b) – Emissions and monitoring effective from 3 December 2023, Table S3.1:

- Dioxins / furans (I-TEQ) – monthly long-term sampling monitoring is not required
- Mercury and its compounds – bi-annual periodic monitoring is not required

As per footnote 1 in Schedule 3(b) Table S3.1 continuous monitoring of mercury and its compounds does not apply for plants incinerating wastes with a proven low and stable mercury content. We will review the monitoring requirement for continuous monitoring of mercury and its compounds following submission of such proof.

Yours sincerely,

**Rebecca Williams**

**Lead Specialist Permitting Officer**