



Ymddiriedolaeth  
Genedlaethol  
National Trust

geraldine.donovan@nationaltrust.org.uk  
Llinell uniongyrchol / Direct line: +44 (0) 2920 590803  
Date 25<sup>th</sup> June 2019

AN0174601

Ms Kirsty Lewis,  
Environment Officer  
Natural Resources Wales  
Plas Yr Afon  
St Mellons Business Park,  
Fortran Road,  
St Mellons,  
Cardiff,  
CF3 0EY

Issued by POST and email to Kirsty.Lewis@cyfoethnaturiolcymru.gov.uk

Annwyl Kirsty / Dear Kirsty

**Re NRW CAR Report ID reference CAR\_NRW0034763**

Thank you for your email of 4<sup>th</sup> June with the above report attached. I can confirm that the actions listed within the report have been carried out. The status of each action is summarised in the following table

	Actions	Status
1	Investigate & Produce a report on findings.	Completed in 2018
2	Repair Internal pipework	Blocked pipes were all unblocked
3	Replace probes and cables which operate the pump floats	Upon investigation specialist engineer got the inhibit float, which was causing part of the problem to operate satisfactorily without need to replace parts
4	Replace aeration pumps in the secondary chamber	Replaced

Dyffryn Gardens / Gerddi Dyffryn  
St Nicholas / Sain Nicolas  
Vale of Glamorgan / Bro Morgannwg  
CF5 6SU

Ffôn / Tel: 02920 593328  
[www.nationaltrust.org.uk](http://www.nationaltrust.org.uk)

Enillydd Lleoedd Arbennig 2015 & 2016/  
Winner of Special Places 2015 & 2016

Llywydd / President: EFB Tywysog Cymru / HRH The Prince of Wales  
Cadeirydd / Chairman: Tim Parker  
Cyfarwyddwr Cyffredinol / Director-General: Dame Helen Ghosh DCB  
Cyfarwyddwr Cymru / Director for Wales: Justin Albert

Swyddfa gofrestredig / Registered office:  
Heelis, Kemble Drive, Swindon, Wiltshire SN2 2NA  
Rhif elusen gofrestredig / Registered charity number 205846

5	Regular desludging of primary tank is required	Ongoing
6	Final Effluent sample chamber to be clearly marked	Sign in place – clearly marking sample point
7	Regular checks of the plant to be implemented into maintenance regime	Incorporated into daily routine of Maintenance Officer
8	Fully functional alarm system to alert staff to issues arising	Flashing beacon repaired and operational
9	Notify NRW of any issues arising on site	Incorporated into daily routine of Maintenance Officer

I trust you will find this response satisfactory. I would also mention that we are in the process of commissioning specialist designers to draw up proposals and costings for the upgrade/replacement of the sewage plant which we are anticipating we will be implementing in a few years' time. We would be grateful for the opportunity to discuss these proposals with you at a later date.

Yn gywir / Yours sincerely

**Gerry Donovan**

Geraldine Donovan  
General Manager