

Schedule 5 Notification

PART A

Permit Number:	BR9715B
Name of Operator:	Solutia UK Ltd
Location of Installation:	Corporation Road, Newport, Gwent, NP194XF
Location of the emission:	Site Effluent Discharge W1
Time and date of the emission:	23/11/22 16:05, and 24/11/22 04:30

Substance(s) emitted	Media e.g. air /water	Best estimate of the quantity or the rate of emission	Time during which the emission took place
Rainfall (surface water) and treated effluent	Estuary	~1400 m3* on each occasion (TBC) *Based on nominal max flowrate	4 hours post the times specified above

Description of the failure or accident, and... Measures taken, or intended to be taken, to stop the emission:	Due to the heavy rainfall experienced in the preceding days, this has necessitated effluent discharge during the cease-discharge period in order to prevent site flooding Pumps being reconfigured to increase pumping capacity Further information to follow in Part B
--	--

* Signed:



Date: 24/11/2022

* authorised to sign on behalf of Solutia UK Ltd