

Schedule 5 Notification

PART A

Permit Number:	BR9715B
Name of Operator:	Solutia UK Ltd
Location of Installation:	Corporation Road, Newport, Gwent, NP194XF
Location of the emission:	Site Effluent – Permit Ref: W1
Time and date of the emission:	30/09/21 [Notified] - See dates & times below:

Substance(s) emitted	Media e.g. air /water	Best estimate of the quantity or the rate of emission	Time during which the emission took place
Treated Effluent	Estuary	Nominal discharge rate: 100m ³ /hr	Cease Discharge Times, and pumping duration(s): • 28/09/21 15:16 35mins • 29/09/21 03:37 150mins • 29/09/21 15:58 90mins • 30/09/21 04:33 180mins

Description of the failure or accident, and... Measures taken, or intended to be taken, to stop the emission:	Due to periods of heavy rainfall in combination with a time limited repair on the site effluent pipeline (due to tidal and wildlife protection restrictions), this necessitated some periods of effluent pumping within the permit designated 'cease discharge' (reduced dilution) period The pumping was necessary to avoid the effluent system being overwhelmed & causing flooding whilst the effluent pipeline was isolated to carry out the repair. This work has been completed, and the cease discharge period can now be observed
--	---

* Signed:



Date: 30/09/2021

* authorised to sign on behalf of Solutia UK Ltd