

Schedule 5 – Notification

PART B

Permit Number:	BR9715IB
Name of Operator:	Solutia UK Ltd
Location of Installation:	Corporation Road, Newport, Gwent, NP194XF
Location of the emission:	Boiler 14 (Permit Ref: A2)
Time and date of the emission:	03/07/21 – 29/07/21 [Operational Period]

Any more accurate information on the matters for notification under Part A	The dates of operation of the Boiler 14 back-up unit were as specified in the Part A. After this time the duty Boiler 16 unit was brought back into service, and the statutory samples indicated NOx emissions were compliant thereafter The reason for the extended outage on the main Boiler 16 was due to cracking in the incoming superheater pipework being noted during the maintenance shutdown – This necessitated additional repair work to be carried out prior to the boiler being brought back on-line
Measures taken, or intended to be taken, to prevent a recurrence of the incident	The failed pipework is to be included in subsequent Boiler 16 inspections
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission	None proposed
The dates of any unauthorised emissions from the installation in the preceding 24 months	09/09/2021 - Offsite Effluent Pipeline 21/08/2021 - Boiler 14 NOx [This Notification] 30/06/2021 - Dequest Formalin Pump Leak 09/06/2021 - Effluent Pipeline leak 22/01/2021 - Dequest Scrub Water Tank Overflow

	23/12/2020 - Effluent Flood Discharge 31/10/2020 - Amino Stripper 20/08/2020 - GT Water Injection Unit 09/06/2020 - T66 Pumphouse 20/04/2020 - Biphenyl Vent 08/10/2019 - PCP in Effluent
--	--

*** Signed:** 

Date: 03/12/2021

* authorised to sign on behalf of Solutia UK Ltd