

Schedule 5 Notification

PART A

Permit Number:	BR9715B
Name of Operator:	Solutia UK Ltd
Location of Installation:	Corporation Road, Newport, Gwent, NP194XF
Location of the emission:	Boiler 14 (Permit Ref: A2)
Time and date of the emission:	03/07/21 – 29/07/21 [Operational Period]

Substance(s) emitted	Media e.g. air /water	Best estimate of the quantity or the rate of emission	Time during which the emission took place
NOx	Emission to atmosphere	NOx concentration of 173 mg/Nm3 Vs 150 mg/Nm3 emission limit	Monitoring Period: 26/07/21 10:57 – 11:11

Description of the failure or accident, and... Measures taken, or intended to be taken, to stop the emission:	Due to extended maintenance work on the main site Boiler (Boiler 16), the back-up unit (Boiler 14) was in operation for more than 14 days, thereby necessitating an emissions test as per Permit requirement [Table S3.1 Note 2] - the results of which were in excess of the emission limit for NOx Further information to follow in Part B
--	--

* Signed: 

Date: 04/08/2021

* authorised to sign on behalf of Solutia UK Ltd