

Permit Number: EPR/BB3097ZS

Operator: Veolia Energy & Utility Services UK Plc

Facility: PB Gelatins boiler house

Form Number: Air1 / 11/01/19

Reporting of emissions to air for the period from 31/12/2020 to 31/12/2021


Emission							
Emission Point	Substance / Parameter	Limit Value	Reference Period	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Uncertainty ^[4]
EP1	Oxides of nitrogen (NO and NO ₂ expressed as NO ₂)	No limit set	Hourly average	131.8	TGN M5	13/12/2021 10:41 - 11:41	6.55
EP1	Carbon monoxide	No limit set	Hourly average	7.48	TGN M5	As above	2.46
EP2	Oxides of nitrogen (NO and NO ₂ expressed as NO ₂)	No limit set	Hourly average	114.4	TGN M5	13/12/2021 11:56 - 12:56	8.41
EP2	Carbon monoxide	No limit set	Hourly average	3.83	TGN M5	As above	1.82
EP3	Oxides of nitrogen (NO and NO ₂ expressed as NO ₂)	No limit set	Hourly average	157	TGN M5	13/12/2021 13:14 - 14:14	12.1
EP3	Carbon monoxide	No limit set	Hourly average	3.13	TGN M5	As above	1.79

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with Natural Resources Wales is used, then the appropriate identifier is given. In other cases the principal technique is stated, for example gas chromatography.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.

[4] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

Signed 
(Authorised to sign as representative of Operator)

Date 18/01/2022

Permit Number: EPR/BB3097ZS

Operator: Veolia Energy & Utility Services UK Plc


Facility: PB Gelatins boiler house

Form Number: WaterUsage1 / 11/01/19

Reporting of Water Usage for the year 2021

Water Source	Usage (m ³ /year)	Specific Usage (m ³ /unit output)
Mains water Grade 1/Grade 3	28m3/1345m3	
TOTAL WATER USAGE	1373m3	Not Applicable (see 'Operator's Comments')

Operator's comments For the period ending 31/12/2021 we are unable to report the figures for steam generation due to a failure of the client's steam meters. The Grade 1/Grade 3 water supplies noted above only represent emergency supplies to the boilerhouse, with the remainder of the process water being supplied by the client.

Signed 
(authorised to sign as representative of Operator)

Date 18/01/2022

Permit Number: EPR/BB3097ZS

Operator: Veolia Energy & Utility Services UK Plc

Facility: PB Gelatins boiler house


Form Number: Energy1 / 11/01/19

Reporting of Energy Usage for the year 2021

Energy Source	Energy Usage		Specific Usage (MWh/unit output)
	Quantity	Primary Energy (MWh)	
Natural Gas	MWh	74,188MWh	N/A
Gas Oil	tonnes	206.2t	N/A
TOTAL	-	76,790MWh	N/A

Operator's comments :

No specific usage is reported for the period due to a failure of the client's steam meters

Signed 
(Authorised to sign as representative of Operator)

Date..... 18/01/2022

Permit Number: EPR/BB3097ZS

Operator: Veolia Energy & Utility Services UK Plc


Facility: PB Gelatins boiler house

Form Number: Performance1 / 11/01/19

Reporting of other performance indicators for the period 31/12/2020 to 31/12/2021

Parameter	Units
Steam production	tonnes N/A

Operator's comments :
Steam generation not reported for the period due to a failure of the client's steam meters.

Signed 
(Authorised to sign as representative of Operator)

Date..... 18/01/2022