

WATER SPOT CHECK SAMPLING

Site Name:	Ffos-y-fran Land Reclamation Scheme		
Permit No:	EPR/DB3131AF	Month:	November 2022 (No samples taken 15.11.22)

Reporting of emissions to water (other than to sewer)

Consent Number	Suspended Solids Consent limits	pH Consent limits	Date of Sample	Discharge Status	pH result	Susp solids result	Weather Conditions
AN0264601 (WC1 Final Effluent)	50 mg/l	5-9	N/A	Not Discharging	N/A	N/A	
AN0264602 (WC1 Storm)	N/A	N/A	N/A	Not Discharging	N/A	N/A	
NPSWQD000674 (WI Final Effluent)	50 mg/l	5-9	N/A	Not Discharging	N/A	N/A	
NPSWQD002105 (WI Storm)	N/A	N/A	N/A	Not Discharging	N/A	N/A	
AN0264501 (WB Final Effluent)	50 mg/l	5-9	N/A	Not Discharging	N/A	N/A	
AN0264502 (WB Storm)	N/A	N/A	N/A	Not Discharging	N/A	N/A	
AN0264603 (WC Final Effluent)	50 mg/l	5-9	N/A	Not Discharging	N/A	N/A	
AN0274601 (WC Storm)	N/A	N/A	N/A	Not Discharging	N/A	N/A	
AN0265001 (WG Final Effluent)	50 mg/l	5-9	N/A	Not Discharging	N/A	N/A	
AN0265002 (WG Storm)	N/A	N/A	N/A	Not Discharging	N/A	N/A	
AN0264801 (WF Final Effluent)	50 mg/l	5-9	N/A	Not Discharging	N/A	N/A	
AN0264802 (WF Storm)	N/A	N/A	N/A	Not Discharging	N/A	N/A	
AN0264401 (WA Final Effluent)	50 mg/l	5-9	N/A	N/A	N/A	N/A	
AN0264402 (WA Storm)	N/A	N/A	N/A	N/A	N/A	N/A	

Notes:

No discharge on this day.

WA has not yet been constructed.

Name	S. Woolmington	Position:	Engineer	Date:	15.11.22
------	----------------	-----------	----------	-------	----------