

 Navigator	Draining of Lagoon	Document Number NTW-OPS-PROC-0027
Document Owner Adam Gibson	Applies to: Navigator Terminals Windmill	Issue Number 5

Appendix 1

Site Name: Navigator Terminals Windmill Ltd

Permit Number: KP3734SH

Parameter	Analytical method	Value recorded	Permit limits	Within permit limits? (Y/N)
pH	Standard glass probe [Dow procedure CTM 0007]	7.967	6 > pH > 10	Y.
Visible oil/grease (Appearance)	Visual examination [CTM 0176]		Must be Y / pass on appearance	
Total Organic Carbon	GC and FID [Dow procedure CTM 1144]	< 2.00	10ppm	Y.

Date: 10.01.23

Results reviewed and acceptable to discharge? (Y/N): Y.

(if not please follow step 6 onwards in procedure NTW-OPS-PROC-0027)

Quantity to discharge (approx.): 1100mm.

Name: L YEOMAN

Signature: 

Sample Results Print



This report contains details of one or more Sample records. This report was generated using the Print Sample menu option and the 'Sample Results Print' report layout.

Id Numeric : 2373752
Sample : SM-9-JAN-2023-612363
Status : C

Sample Results List

Analysis	Component Name	Type	Result	Units	Status
0176\$OIL/5	Appearance - Oil sheen	O	Pass - No Visible Oil sheen		E
0007\$A/1	pH	N	7.967		E
1144\$B/7	Total Carbon (TC)	N	11.62	mg/liter	E
1144\$B/7	Total Inorganic Carbon (TIC)	N	10.82	mg/liter	E
1144\$B/7	Total Organic carbon (TOC)	K	<2.00	mg/liter	M

LAGOONWTR - Navigator Lagoon Run Off
Water

Hazard.....: Non-Hazardous
 LoginDate...: 09-JAN-2023 09:33
 Size.....: 1 x 500ml
 Notes.....:
 0007\$A - pH (as received)
 0176\$OIL - No Visible Oil
 1144\$B - TOC ONLY

2373752 W212