

CONSENT NO:	NRWWIA164
SCHEDULE NO:	NRWWIA164-01
DATE ISSUED:	21 st August 2019

CONDITIONS OF CONSENT TO DISCHARGE DE-CHLORINATED WATER (“the Discharge”)

NATURE OF THE DISCHARGE

1. The Discharge shall consist solely of de-chlorinated water.

SOURCE OF THE DISCHARGE

2. The Discharge shall be derived from Nantylwch Waste Water Treatment Works, Waterworks Lane, Tredegar NP22 4EP.

LOCATION OF DISCHARGE

3. The location of the Discharge shall be at NGR SO 13148 11402, marked ‘Discharge Point’ on the site plan in Annex 1.

SAMPLE POINT

4. A sample point shall be provided and maintained so that a representative sample of the Discharge may be obtained.

VOLUME

5. The total volume of the Discharge shall not exceed 2475 cubic metres.
6. The total daily volume of the Discharge shall not exceed 1237.5 cubic metres.
7. The rate of the Discharge shall not exceed 14.3 litres per second.

COMPOSITION

8. The consent holder shall take all necessary steps to secure that any water discharged by it under this consent is as free as may be reasonably practicable from —
 - (a) mud and silt;
 - (b) solid, polluting, offensive or injurious substances;
and
 - (c) any substances prejudicial to fish or spawn, or to spawning beds or food of fish.

CONSENT NO:	NRWWIA164
SCHEDULE NO:	NRWWIA164-01
DATE ISSUED:	21 st August 2019

SCOURING

9. The rate of discharge shall be controlled to prevent any significant scouring of the bed or bankside of the receiving water.

FLOODING

10. The discharge shall not cause or significantly contribute to flooding in the downstream catchment.

PERIOD OF DISCHARGE

11. The Discharge shall only be made between 21st day of August 2019 and the 28th day of August 2019.

CONSENT NO:	NRWWIA164
DATE ISSUED:	21 st August 2019

ANNEX 1- PLAN No. NRWWIA164

