

Permit Reference Number: BL3986ID

Operator: Tarmac Cement & Lime Ltd

Installation: Aberthaw Works

Form Number: Water 1 / 19/07/16

**Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2
for the period 1.10.22 – 31.10.22**

Emission Point	Parameter	Emission Limit Value	Result	Date of Measurement	Method
W1	pH (minimum)	6	7.9	28/10/22	BS ISO10523
W1	pH (maximum)	9	-	-	BS ISO10523
W1	Total Suspended Solids (Maximum)	50 mg/l	10.9	28/10/22	BS EN 872
W1	Oil or Grease	None Present	None Visible	28/10/22	Visual Check
W2	pH (minimum)	6	-	-	BS ISO10523
W2	pH (maximum)	9	-	-	BS ISO10523
W2	Total Suspended Solids (Maximum)	50 mg/l	-	-	BS EN 872
W2	Oil or Grease	None Present	-	-	Visual Check

Signed : D Bound Date : 11.01.2023
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

Permit Reference Number: BL3986ID

Operator: Tarmac Cement & Lime Ltd

Installation: Aberthaw Works

Form Number: Water 1 / 19/07/16

**Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2
for the period 1.11.22 – 30.11.22**

Emission Point	Parameter	Emission Limit Value	Result	Date of Measurement	Method
W1	pH (minimum)	6	7.83	28/11/22	BS ISO10523
W1	pH (maximum)	9	-	-	BS ISO10523
W1	Total Suspended Solids (Maximum)	50 mg/l	4.45	28/11/22	BS EN 872
W1	Oil or Grease	None Present	None Visible	28/11/22	Visual Check
W2	pH (minimum)	6	-	-	BS ISO10523
W2	pH (maximum)	9	-	-	BS ISO10523
W2	Total Suspended Solids (Maximum)	50 mg/l	-	-	BS EN 872
W2	Oil or Grease	None Present	-	-	Visual Check

Signed : D Bound
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

Date : 11.01.2023

Operator: Tarmac Cement & Lime Ltd

Form Number: Water 1 / 19/07/16

**Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2
for the period 1.12.22 – 31.12.22**

Emission Point	Parameter	Emission Limit Value	Result	Date of Measurement	Method
W1	pH (minimum)	6	8.01	29/12/22	BS ISO10523
W1	pH (maximum)	9	-	-	BS ISO10523
W1	Total Suspended Solids (Maximum)	50 mg/l	4.9	29/12/22	BS EN 872
W1	Oil or Grease	None Present	None Visible	29/12/22	Visual Check
W2	pH (minimum)	6	-	-	BS ISO10523
W2	pH (maximum)	9	-	-	BS ISO10523
W2	Total Suspended Solids (Maximum)	50 mg/l	-	-	BS EN 872
W2	Oil or Grease	None Present	-	-	Visual Check

Signed : D Bound Date : 11.01.2023
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)