

Permit Reference Number: BL3986ID

Installation: Aberthaw Works

Operator: Tarmac Cement & Lime Ltd

Form Number: Water 1 / 19/07/16

**Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2
for the period 01/07/18 to 31/07/18**

Emission Point	Parameter	Emission Limit Value	Result	Date of Measurement	Method
W1	pH (minimum)	6	8.0	19.07.2018	BS ISO10523
W1	pH (maximum)	9	-	-	BS ISO10523
W1	Total Suspended Solids (Maximum)	50 mg/l	<5.0 mg/l	19.07.2018	BS EN 872
W1	Oil or Grease	None Present	None Visible	19.07.2018	Visual Check
W2	pH (minimum)	6	-	-	BS ISO10523
W2	pH (maximum)	9	-	-	BS ISO10523
W2	Total Suspended Solids (Maximum)	50 mg/l	-	-	BS EN 872
W2	Oil or Grease	None Present	-	-	Visual Check

Signed : K. Bennett
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

Date :25.10.2018


26/10/18

Permit Reference Number: BL3986ID

Installation: Aberthaw Works

Operator: Tarmac Cement & Lime Ltd

Form Number: Water 1 / 19/07/16

**Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2
for the period 01/08/18 to 31/08/18**

Emission Point	Parameter	Emission Limit Value	Result	Date of Measurement	Method
W1	pH (minimum)	6	8.2	24.08.2018	BS ISO10523
W1	pH (maximum)	9	-	-	BS ISO10523
W1	Total Suspended Solids (Maximum)	50 mg/l	<5.0 mg/l	24.08.2018	BS EN 872
W1	Oil or Grease	None Present	None Visible	24.08.2018	Visual Check
W2	pH (minimum)	6	-	-	BS ISO10523
W2	pH (maximum)	9	-	-	BS ISO10523
W2	Total Suspended Solids (Maximum)	50 mg/l	-	-	BS EN 872
W2	Oil or Grease	None Present	-	-	Visual Check

Signed : K. Bennett
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

Date :26.10.2018

Permit Reference Number: BL3986ID

Installation: Aberthaw Works

Operator: Tarmac Cement & Lime Ltd

Form Number: Water 1 / 19/07/16

Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2
for the period 01/09/18 to 30/09/18

Emission Point	Parameter	Emission Limit Value	Result	Date of Measurement	Method
W1	pH (minimum)	6	7.7	27.09.2018	BS ISO10523
W1	pH (maximum)	9	-	-	BS ISO10523
W1	Total Suspended Solids (Maximum)	50 mg/l	<5.0 mg/l	27.09.2018	BS EN 872
W1	Oil or Grease	None Present	None Visible	27.09.2018	Visual Check
W2	pH (minimum)	6	-	-	BS ISO10523
W2	pH (maximum)	9	-	-	BS ISO10523
W2	Total Suspended Solids (Maximum)	50 mg/l	-	-	BS EN 872
W2	Oil or Grease	None Present	-	-	Visual Check

Signed : K. Bennett
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

Date :26.10.2018

 26/10/18