

CONSENT NO.	CM0052101
-------------	-----------



ASiantaeth Yr
Amgylchedd Cymru
Environment
Agency Wales

**WATER RESOURCES ACT 1991
SECTION 88 - SCHEDULE 10
(AS AMENDED BY THE ENVIRONMENT ACT 1995)
NOTICE OF MODIFICATION OF CONSENT TO DISCHARGE**

**TO: Dŵr Cymru Cyf
Pentwyn Road
Nelson
Treharris
Mid Glamorgan
CH46 6LY**

WHEREAS the **ENVIRONMENT AGENCY** in pursuance of its powers under Schedule 10 to the Water Resources Act 1991 granted on 26th day of May 1981 CM0052101 permitting the discharge of Treated Sewage Effluent

FROM: CERRIGYDRUDION STW

AT: SH 95160 48330

TO: Nug

NOTICE IS HEREBY given by the **ENVIRONMENT AGENCY** that, following the publication of the PR04 agreed programme for sewerage undertakers in England and Wales, and in pursuance of its powers under the paragraph 7(2) of Schedule 10 to the Water Resources Act 1991, the said Consent is **MODIFIED** as follows:

A. Modify the wording of condition 2 attached to CM0052101:

2. Determinand:

The limits set out below may be exceeded where, in any series of samples taken in the period of 12 months ending on the date of the discharge, as listed in column 1 of Annex 1 attached to this consent no more than the relevant number of samples, as listed in Column 2 of the said Annex, exceeds the applicable limit for that determinand at the time when a sample is taken.

- (i) The biological oxygen demand (ATU) in 5 days at 20°C shall not exceed 40 milligrams per litre
- (ii) The suspended solids dried at 105°C shall not exceed 60 milligrams per litre.
- (iii) The ammonical nitrogen (expressed as N) shall not exceed 20 milligrams per litre.
- (iv) pH value (maximum range): 5-9
- (v) Rate of discharge: 6.4l/s
- (vi) Volume during any period of 24 consecutive hours: 546 cu.m.
- (vii) Volume discharged under 'dry weather conditions' during any period of 24 consecutive hours: 91cu.m.





ASiantaeth Yr
Amgylchedd Cymru
ENVIRONMENT
AGENCY WALES

Subject to the provisions of Paragraphs 7 and 8 of Schedule 10 to the Water Resources Act 1991, no notice shall be served by the Agency, which alters the effect of modifications made by this notice, without the agreement in writing of the Consent Holder, during a period of 4 years from the date this notice is served.

This modification is served on 31st March 2005
This modification takes effect on 31st day of March 2008

Signed *Iwan Williams*
Iwan Williams
Regulatory Team Leader (Water Quality)

NOTE. All other conditions of this consent remain unaltered and in force. This notice of modification should be read in conjunction with, CM0052101

CONSENT AMENDMENTS

CONSENT NO	SCHEDULE NO	DATE MODIFICATION ISSUED
CM0052101		31 st March 2005
CONDITIONS : UNCHANGED		
1		
CONDITIONS: MODIFIED		DATE ON WHICH NEW OR REVISED CONDITIONS COME INTO FORCE
2		31 st day of March 2008

