

Water Resources Act 1991
as amended by the Environment Act 1995
Consent to Discharge
Certificate of Holder



**ENVIRONMENT
AGENCY**

Part A

To: DWR CYMRU CYFYNGEDIG
CONSENTS REGULATION OFFICER
PLAS-Y-FFYNNON
CAMBRIAN WAY
BRECON LD3 7HP

The **Environment Agency** ("the Agency") hereby confirm that the above named person is a/the registered holder of consent BN0000302

Nature of Discharge(s); SEWAGE EFF/TREATED EFF/CONTINUOUS
at
BRECHFA STW

Note: This certificate should be kept with the consent document for future reference. If you transfer responsibility for the discharge to somebody else you must pass the consent to them and tell the Agency within 21 days. **Responsibility for the consent cannot be disclaimed by the holder but the registration of holder may be transferred to a successor.** To do this please complete the form below, then tear it off and return it to the address shown. If you fail to transfer the consent, even though you are no longer on the site, you may still be liable for prosecution for pollution. If you transfer the consent but do not tell us, you will be committing an offence. In case of any queries please contact your local Environment Agency office.

Part B Please complete in block capitals or type.

To:

Water Resources Act 1991: Notice of transfer of consent to discharge

Consent:

Name:

Address:

I/We* hereby serve notice on the Agency that I/we* am/are* no longer a/the* Holder of the above consent which will be/was* transferred to:

* delete as appropriate

Name(s) of new holder(s):

Address:

Post Code:

Date of Transfer to new Holder(s);

Signed:..... **Dated:**.....

Name (block capitals): **Position:**



Welsh Off Ref

Form SS.RW2

WWA HQ Ref

RW/0551/1/1

Sheet 1
of 1

LOCAL GOVERNMENT ACT 1972 WATER ACT 1973
RIVERS (PREVENTION OF POLLUTION) ACTS 1951-1961
WATER AUTHORITIES (CONTROL OF DISCHARGES) ORDER 1978

NOTIFICATION OF VARIATION OF CONSENT
for a discharge of treated sewage effluent

To : WELSH WATER AUTHORITY

This Notice is issued under the above-mentioned Acts and Order and all other enabling powers as a NOTICE DEEMED TO HAVE BEEN GIVEN BY THE SECRETARY OF STATE FOR WALES, in respect of the existing discharge of treated sewage effluent from the Authority's :

BRECHFA SEWAGE TREATMENT WORKS

via an existing outlet and subject hitherto to a previous consent as specified below.

THE EXISTING OUTLET is to : the Afon Marlais

at National Grid Reference : SN 5305 3015

and has been shown marked : Discharge Point

on the attached Plan, No. : RW/0551/1/1

THE PREVIOUS CONSENT was : The Consent Reference No. -

granted on : 6th January 1967

by : South West Wales River Authority

to : Newcastle Emlyn R.D.C. and Llandeilo R.D.C.

The Authority submitted this Notification of Variation on : 12th November 1981 to the Secretary of State for Wales in the form of a draft and the Secretary of State has NOT, within the relevant period, given notice of his intention to determine this matter. This discharge is therefore (in substitution for all the conditions hitherto in force) subject only to the following conditions as from : 12th February 1982

CONDITIONS

1. The discharge shall consist only of treated sewage effluent from the above works.
2. The quality and quantity of effluent shall not exceed the following maximum values:

<u>Determinand</u>	<u>Value</u>	<u>Unit</u>
Biochemical Oxygen Demand (+ATU) over 5 days at 20°C	37	milligrams per litre
Suspended Solids dried at 105°C	35	milligrams per litre

Rate of discharge	2.1	litres per second
Volume during any period of 24 consecutive hours	175	cubic metres
Volume discharged under 'dry weather conditions' during any period of 24 consecutive hours	43.6	cubic metres

3. Adequate facilities shall be provided for the taking of samples of the effluent at: outlet from humus tank

The terms of this Notice will not, without the consent in writing of the person to whom this Notice is given, (or his successor), be altered before the expiration of the period ending with the Twelfth day of February 1984.

This Notification is issued by the Directorate of Scientific Services, Headquarters, Welsh Water Authority, Cambrian Way, Brecon, Powys.

SOUTH WEST WALES RIVER AUTHORITY
RIVERS (PREVENTION OF POLLUTION) ACTS, 1951-1961

Consent to discharge of effluent.

The South West Wales River Authority pursuant to the provisions of the above mentioned Acts, hereby consent to the construction of an outlet and to the discharge of effluent therefrom upon the following conditions:—

1. NAME AND ADDRESS OF PERSON to whom consent is given

The Clerk, Newcastle Emlyn Rural District Council, Pont-twelly, Llanysfaul, Carmar.

2. PREMISES to which consent relates

Brechfa Joint Sewerage Scheme. Emergency overflow main pumping station.

3. OUTLET

- (a) Location—situated on right/left bank of River Marlais a tributary of the River
Map reference Sheet SM, Grid reference 5267 3022
- (b) Construction— 6" diameter asbestos cement Pipe
- (c) Use—restricted to Sewage/Storm Sewage/Trade/Farm Effluent produced at the above mentioned premises.

4. DISCHARGE

- (a) Nature Sewage effluent
- (b) Volume or rate of discharge 300 g.p.h. (Emergency discharge to operate only in the event of a complete electrical failure)
Maximum rate of discharge
- (c) Temperature not to exceed 21 °C.
- (d) Composition:—
- (i) pH value not less than 6.0 or more than 8.5
 - (ii) Suspended solids not more than p.p.m.
 - (iii) Dissolved solids not more than p.p.m.
 - (iv) 5 day B.O.D. at 20°C. not more than p.p.m.
 - (v) Oxygen absorbed from acid permanganate in 3 mins at 27°C. not more than p.p.m.
4 hrs.
 - (vi) Ammoniacal nitrogen (as N) not more than p.p.m.
 - (vii) Effluent shall pass the methylene blue stability test (5 days at 20°C.)
 - (viii) Effluent shall not contain any other polluting substance or substances in concentrations toxic to fish and other animals.

Screened sewage, partially settled.

(e) Sampling point to be located at point of outlet.

TERMS OF CONSENT

This consent will not without the consent in writing of the person to whom this consent is given be valid after the expiration of the period ending with the 31st day of March 1971.

Dated this 5th day of March 1971.

Clerk of the Authority.

