



ENVIRONMENT
AGENCY

Water Resources Act 1991
as amended by the Environment Act 1995
Consent to Discharge
Certificate of Holder

Part A

To: DWR CYMRU CYFYNGEDIG

CONSENTS REGULATION OFFICER

PLAS-Y-FFYNNON

CAMBRIAN WAY

BRECON LD3 7HP

The Environment Agency ("the Agency") hereby confirm that the above named person is a/the registered holder of consent BG0007801

Nature of Discharge(s): SEWAGE EFF/TREATED EFF/CONTINUOUS
at
PENCADER STW

Note: This certificate should be kept with the consent document for future reference. If you transfer responsibility for the discharge to somebody else you must pass the consent to them and tell the Agency within 21 days. Responsibility for the consent cannot be disclaimed by the holder but the registration of holder may be transferred to a successor. To do this please complete the form below, then tear it off and return it to the address shown. If you fail to transfer the consent, even though you are no longer on the site, you may still be liable for prosecution for pollution. If you transfer the consent but do not tell us, you will be committing an offence. In case of any queries please contact your local Environment Agency office.

Part B Please complete in block capitals or type.

To:

Water Resources Act 1991: Notice of transfer of consent to discharge

Consent:

Name:

Address:

I/We* hereby serve notice on the Agency that I/we* am/are* no longer a/the* Holder of the above consent which will be/was* transferred to:

* delete as appropriate

Name(s) of new holder(s):

Address:

Post Code:

Date of Transfer to new Holder(s):

Signed:

Dated:


Name (block capitals):

Position:

IVES206

(to be completed when signing
on behalf of Environment Agency)





CONSENT VARIATION

WEP/24/D5

RIVERS (CONTROL OF POLLUTION) ACTS 1951-1961

THE WATER AUTHORITIES (CONTROL OF DISCHARGES) ORDER 1978

I am directed by the Secretary of State for Wales to refer to the discharge consent in respect of the PENYCADDER..... sewage treatment works dated 15. SEPTEMBER 1970.

The Secretary of State for Wales, having consulted with the Welsh Water Authority, hereby gives notice that in exercise of his powers under Articles 4(8) and 8 of the Water Authorities (Control of Discharges) Order 1978 (SI 1978 No 1210), the conditions imposed on the said consent shall be varied in the following terms:

CONDITIONS

The quality and quantity of effluent shall not exceed the following maximum values:

Biochemical Oxygen Demand (+ ATU) over 5 days at 20°C;.....20..... milligrammes per litre.

Suspended Solids dried at 105°C;30..... milligrammes per litre.

Ammoniacal ammonia expressed as nitrogen1..... milligrammes per litre.

Dry Weather Flow litres per second or 4.39..... metres cubed per day.

Maximum rate of flow 20 litres per second or 1728 metres cubed per day.

This variation takes effect from the 30 January 1985.

This notice should be retained with the consent dated 15. SEPTEMBER 1970.

David Roberts
WEP Division
Welsh Office

660007801

Scheme No. G.S. 365. (a)

SOUTH WEST WALES RIVER AUTHORITY

RIVERS (PREVENTION OF POLLUTION) ACTS, 1951-1961

Consent to discharge of effluent

The South West Wales River Authority pursuant to the provisions of the above mentioned Acts, hereby consent to the construction of an outlet and to the discharge of effluent therefrom upon the following conditions:—

1. NAME AND ADDRESS OF PERSON to whom consent is given

Newcastle Emlyn Rural District Council,
Council Offices, Pentwelly, Llandysul.

2. PREMISES to which consent relates

Pencader Sewage Treatment Works.

3. OUTLET

(a) Location—situated on right/left bank of River Tywelli.

Map reference OS 24 43, Grid reference 446 365
Construction—6" diameter Pipe

(c) Use—restricted to Sewage/Storm Sewage/Trade/Factory Effluent produced at the above mentioned premises.

4. DISCHARGE

(a) Nature ~~Sewage~~

(b) Volume or rate of discharge 56,720 g.p.d. (d.w.f.) + 40,000 g.p.d.
Maximum rate of discharge 96,720 g.p.d. (d.w.f.) + 40,000 g.p.d.
Infiltration normal.

(c) Temperature not to exceed 21 °C.

(d) Composition:—

(i) pH value not less than 6.0 or more than 8.5

(ii) Suspended solids not more than 30 p.p.m.

(iii) Dissolved solids not more than 300 p.p.m.

(iv) 5 day B.O.D. at 20°C. not more than 20 p.p.m.

(v) Oxygen absorbed from acid permanganate in 3 mins not more than 3 p.p.m.

4 mins not more than 4 p.p.m.

(vi) Ammoniacal nitrogen (as N) not more than 10 p.p.m.

(vii) Effluent shall pass the methylene blue stability test (5 days at 20°C.)

(viii) Effluent shall not contain any other polluting substance or substances in concentrations toxic to fish and other animals.

(e) Sampling point to be located at point of outlet.

5. PERIOD OF CONSENT

The terms of this consent will not without the consent in writing of the person to whom this consent is given be altered before the expiration of the period ending with the 30th day of September, 1972.

Dated this 15th day of September, 1970.

Clerk of the Authority.

BG 00078 0
BG 00078 0
BG 00078 0
BG 00078 0

GS/365

