

P.R.
CONSENT NO. BG0007801

creu lle gwell
creating a better place



Asiantaeth yr
Amgylchedd Cymru
Environment
Agency Wales

WATER RESOURCES ACT 1991

SECTION 88 - SCHEDULE 10

(AS AMENDED BY THE ENVIRONMENT ACT 1995)

NOTICE OF MODIFICATION OF CONSENT TO DISCHARGE

TO: Environment Quality Scientist
Dwr Cymru Cyfyngedig
Pentwyn Road
Nelson
Treharris
Mid Glamorgan CF46 6LY

Following a review of the conditions of its consent, the **ENVIRONMENT AGENCY** ("The Agency") in pursuance of its powers under paragraph 7(2)(b) of Schedule 10 to the Water Resources Act 1991 **HEREBY MODIFIES ITS CONSENT** to the making of a discharge **OF TREATED SEWAGE EFFLUENT**,

with respect to Consent No. BG0007801 issued on/dated the 30th day of January 1985

FROM: PENCADER STW

AT: PENCADER

TO: RIVER TYWELLI

as follows:

Addition of the following new conditions as Schedule BG0007801 01/F

NOTE. All other conditions of this consent remain unaltered and in force. This notice of modification should be read in conjunction with, and attached to Schedule 01 of BG0007801

Subject to the provisions of Paragraphs 7 and 8 of Schedule 10 to the Water Resources Act 1991, no notice shall be served by the Agency, which alters the effect of modifications made by this notice, without the agreement in writing of the Consent Holder, during a period of 4 years from the date this notice is served.

This modification is served on 31st day of December 2005
This modification takes effect on 31st day of December 2005

Signed

STUART THOMAS
Regulatory Water Quality Team Leader





CONSENT NO.	BG0007801
SCHEDULE NO.	BG0007801 01/F
DATED	31st December 2005

Conditions to be added :

- F1.** A continuous flow measurement and recording system, to a specification provided by the Agency, shall be provided and operated to record the total daily volume, and the instantaneous or 15-minute integrated flow every 15 minutes of sewage through the treatment works. An on-site visual display from which instantaneous or 15-minute integrated flow readings can be readily obtained by the Agency shall be provided and operated. The Consent Holder shall hold records of the flow readings.
- F2.** As soon as practicable after completion of the flow system installation and subsequently on the expiry of any certificate issued, the Consent Holder shall employ an independent expert to certify that the installation and its quality management system complies with the Agency's specification. The independent expert shall be accredited to a competency scheme approved by the Agency. A copy of the certificate shall be sent to the Agency and the certifier's report shall be provided to the Agency on request. If a certificate issued for a flow system has no expiry date included then the certificate shall be deemed to expire five years after the issue date of the certificate.
- F3.** The Consent Holder shall produce and maintain a documented quality management system, approved by the independent expert and to the satisfaction of the Agency, specifying procedures for the calibration, operation and maintenance of the flow measurement equipment. The flow measurement equipment shall be calibrated, operated and maintained by the Consent Holder in accordance with the provisions of the QMS. The Consent Holder shall keep a record of these procedures available for inspection by the Agency and provide a copy to the Agency on request.
- F4.** The Consent Holder shall record all failures of the continuous flow measurement system and any other breaks in the flow record. The reasons for all significant failures and breaks, which lead to missing or suspect data, and all steps taken to prevent a re-occurrence shall be recorded and details shall be provided to the Agency on request. A failure or break is significant for the purposes of this condition if it prevents the calculation of the total daily volume to the required level of uncertainty. The Consent Holder shall ensure that as far as possible the recorder remains fully operational at all times. Any failures shall be remedied as soon as possible.

CONSENT NO.	BG0007801
SCHEDULE NO.	BG0007801 01/F
DATED	31st December 2005

- F5.** Records of the flow readings or the reasons for any breaks in the record, as described in condition F4 above, shall be provided to the Agency when requested, in a format specified by the Agency.
- F6.** Flows of sewage through the treatment works shall be measured at the location identified by the MCERTS inspector in Report Reference Number TFS006/d2/53.

Other conditions of the consent

All other conditions of the consent remain in force. Consent BG0007801 is updated accordingly.

creu lle gwell
creating a better place



Asiantaeth yr
Amgylchedd Cymru
Environment
Agency Wales

Mr Tony Andrews
Environment Quality Scientist
Dwr Cymru Cyf
Pentwyn Road
Nelson
Treharris
Mid Glamorgan
CF46 6LY

Ein cyf/Our ref: Ceredigion mods
Eich cyf/Your ref:

Dyddiad/Date: 31 January 2006

Dear Mr Andrews

RE: WATER RESOURCES ACT 1991, SCHEDULE 10 (AS AMENDED BY THE ENVIRONMENT ACT 1995) MODIFICATIONS OF CONSENT TO DISCHARGE SEWAGE EFFLUENT BY DWR CYMRU CYF FROM VARIOUS SITES, CEREDIGION

Please find enclosed the Agency's formal notices of the modifications made to the conditions of the following consents:

BN0099101
BN0040202
BG0007801
BG0024901
BP0045001
BN0013701
BH0060601
BP0237901
BP028420101

LLANILAR STW
PONTRHIDFENDIGAID STW
PENCADER STW
LLECHRYD STW
LAMPETER STW
HENLLAN STW
DREFACH/FELINDRE STW
ABERPORTH STW
ABERAERON STW

Yours sincerely

L Lewis
Authorisations Officer

Llinell uniongyrchol/Direct dial 01792 3255
Ffacs uniongyrchol/Direct fax 01792 325530
Encs

Cont'd..

Asiantaeth yr Amgylchedd Cymru
Maes Newydd, Llandarsi,
Castell-Nedd Port Talbot, SA10 6JQ
Llinell gwasanaethau cwsmeriaid: 08708 506 506
Ebost: enquiries@environment-agency.gov.uk
www.asiantaeth-amgylchedd.cymru.gov.uk

Environment Agency Wales
Maes Newydd, Llandarcy, Neath Port Talbot, SA10 6JQ
Customer services line: 08708 506 506
Email: enquiries@environment-agency.gov.uk
www.environment-agency.wales.gov.uk



