

CONSENT NO.	BP0034002
--------------------	------------------

WATER RESOURCES ACT 1991

SECTION 88 - SCHEDULE 10

(AS AMENDED BY THE ENVIRONMENT ACT 1995)

VARIATION OF CONSENT TO DISCHARGE

TO: Dŵr Cymru Cyfyngedig ("the Consent Holder")
c/o Environment Quality Scientist
Pentwyn Road
Nelson
Treharris
CF46 6LY

In pursuance of an application by the consent holder for variation of consent, the **ENVIRONMENT AGENCY** ("The Agency") in pursuance of its powers under the Water Resources Act 1991 **HEREBY VARIES ITS CONSENT** to the making of a discharge **OF SEWAGE EFFLUENTS**, as follows:

Storm Sewage

Sewage in an Emergency

with respect to Consent No. BP0034002 issued on the 7th day of March 2005

FROM: Amroth and Summerhill No.1 (Car Park PS)

AT: Amroth, Pembrokeshire

TO: Colby Stream

SUBJECT TO the conditions set out in the following schedule(s):


Storm Sewage: Schedule No. **BP0034002 01**

Sewage in an Emergency: Schedule No. **BP0034002 02**

Subject to the provisions of Paragraphs 7 and 8 of Schedule 10 of the Water Resources Act 1991, no notice shall be served by the Agency, which alters the effect of variations made to this consent, without the agreement in writing of the consent holder, during a period of 4 years from the date this variation is issued.

This variation of consent is issued on the 11th day of February 2010

and takes effect on the 31st day of March 2010



Signed

Christopher Hall Team Leader – National Permitting

CONSENT NO.	BP0034002
SCHEDULE NO.	BP0034002 01
DATE ISSUED	11/02/10

CONDITIONS OF CONSENT TO DISCHARGE

Storm Sewage (“the Discharge”)

FROM: Amroth and Summerhill No.1 (Car Park PS)

NATURE

1. The Discharge shall consist solely of storm sewage.

LOCATION

2. The Discharge shall be made in the manner and at the place specified as:
 - (a) discharging via a 225mm diameter pipe;
 - (b) discharging to Colby Stream;
 - (c) at National Grid Reference SN 16220 07095
 - (d) shown marked 'OUTFALL POINT' on Plan BP0034002 attached as Annex 1.

SAMPLE POINT

3. A sample point shall be provided and maintained at National Grid Reference SN 16228 07091, as shown marked ‘STORM & EMERGENCY OVERFLOW SAMPLING POINT’ on Plan BP0034002 attached as Annex 1, so that a representative sample of the Discharge may be obtained. The Consent Holder shall ensure that all constituents of the Discharge pass through the said sampling point at all times and in any legal proceedings it shall, for the purposes of Section 10 of the Rivers (Prevention of Pollution) Act 1961, be presumed, until the contrary is shown that any sample of the Discharge taken at the said sampling point is a sample of what was discharging into controlled waters.

VOLUME

4.
 - (a) The Discharge shall occur when, and only for as long as, the storm sewage facility is fully utilised and the rate of flow at the storm overflow chamber is in excess of 18 litres per second due to rainfall and/or snow melt. The storm sewage storage facility shall be emptied and its contents returned to the pass forward flow as soon as practicable after cessation of the overflow.
 - (b) A storm sewage facility of at least 51.7 cubic metres design capacity shall be provided and fully utilised prior to discharge being made.

CONSENT NO.	BP0034002
SCHEDULE NO.	BP0034002 01

COMPOSITION

5.
 - (a) The Discharge shall have passed, without prior comminution or maceration, through a screening device having apertures no greater than 6 millimetres in two dimensions.
 - (b) The screening device shall be maintained in an efficient operational condition.
 - (c) All screenings must be removed and disposed of in a manner such as to prevent entry to the discharge.

MAINTENANCE

6. The overflow shall be maintained in an efficient operational condition.

START DATE

7. Until discharge is permitted under the terms of this consent, the quality of the effluent from Amroth and Summerhill No.1 (Car Park PS) Combined Sewer Overflow shall be controlled under the terms of the consent issued on the 7th of March 2005. There shall be no discharge under the terms of this consent until the 31st of March 2010 or the end of commissioning of the works whichever is sooner. The Consent Holder shall give the Environment Agency at least 28 days written notice before making the discharge.

CONSENT NO.	BP0034002
SCHEDULE NO.	BP0034002 02
DATE ISSUED	11/02/10

CONDITIONS OF CONSENT TO DISCHARGE

Sewage in an Emergency (“the Discharge”)

FROM: Amroth and Summerhill No.1 (Car Park PS)

NATURE

1. The Discharge shall consist solely of sewage in an emergency.
2. The Discharge shall only occur when the sewage pumping station is inoperative as a result of one or more of the following:
 - (i) electrical power failure not due to the act or default of the consent holder, its agents, representatives, officers, employees or servants;
 - (ii) mechanical breakdown of duty and standby pumps;
 - (iii) rising main failure;
 - (iv) blockage of the downstream sewer not due to the act or default of the consent holder, its agents, representatives, officers, employees or servants;

and it is not reasonably practicable to dispose of the sewage otherwise. There shall be no undue delay on the part of the consent holder in remedying any such failure or breakdown.

LOCATION

3. The Discharge shall be made in the manner and at the place specified as:
 - (a) discharging via a 225mm diameter pipe;
 - (b) discharging to Colby Stream;
 - (c) at National Grid Reference SN 16220 07095;
 - (d) shown marked ‘OUTFALL POINT’ on Plan BP0034002 attached as Annex 1.

SAMPLE POINT

4. A sample point shall be provided and maintained at National Grid Reference SN 16228 07091, as shown marked ‘STORM & EMERGENCY OVERFLOW SAMPLING POINT’ on Plan BP0034002 attached as Annex 1, so that a representative sample of the Discharge may be obtained. The Consent Holder shall ensure that all constituents of the Discharge pass through the said sampling point at all times and in any legal proceedings it shall, for the purposes of Section 10 of the Rivers (Prevention of Pollution) Act 1961, be presumed, until the contrary is shown that any sample of the Discharge taken at the said sampling point is a sample of what was discharging into controlled waters.

CONSENT NO.	BP0034002
SCHEDULE NO.	BP0034002 02

VOLUME

5. Storage capacity, equivalent to a total of at least 51.7 cubic metres, shall be provided in the pumping station, above the wet well design top water level.

COMPOSITION

6.
 - (a) The Discharge shall have passed, without prior comminution or maceration, through a screening device having apertures no greater than 10 millimetres in one dimension.
 - (b) The screening device shall be maintained in an efficient operational condition.
 - (c) All screenings must be removed and disposed of in a manner such as to prevent entry to the discharge.

TELEMETRY

7.
 - (a) A 24 hour response telemetry alarm system shall be provided and maintained to give notification of failure or breakdown of the pumping station.
 - (b) The Consent Holder shall take all reasonable remedial measures to return the pumping station to normal operation, as soon as practicable after receipt of warning of failure or breakdown of the pumping station.
 - (c) The Consent Holder shall notify the Agency, as soon as practicable, when there is potential for operation of the emergency overflow in the event of failure or breakdown of the pumping station.

RECORDING AND REPORTING

8.
 - (a) The consent holder shall establish and operate a documented maintenance programme and record all non-routine actions undertaken that may have adversely affected effluent quality. Copies of the programme shall be made available for inspection by the Agency's officers at all reasonable times.
 - (b) On request the consent holder shall supply the Agency with a written report on the maintenance and all non-routine actions that may have adversely affected effluent quality.
 - (c) On request the consent holder shall supply the Agency with a written report on the operation of the emergency overflow.

CONSENT NO.	BP0034002
SCHEDULE NO.	BP0034002 02

OTHER

9. Facilities shall be provided so that a mobile stand-by generator may readily be installed at the pumping station in the event of electrical failure and the Consent Holder shall install and operate such a generator as soon as is practicable after an electrical failure.
10. The duty pump(s) shall be maintained in good working order, and at least one stand-by pump shall be provided and maintained.
11. Stand-by pump(s) shall activate should the duty pump(s) become inoperative for reasons other than power failure. The pumping station shall be maintained so that the pump shall reactivate as soon as is practicable after the power is restored after interruption to the supply.
12. A tanker access facility at an appropriate location shall be provided and maintained to enable removal of sewage by tanker when necessary.

START DATE

13. Until discharge is permitted under the terms of this consent, the quality of the effluent from Amroth and Summerhill No.1 (Car Park PS) Emergency Overflow shall be controlled under the terms of the consent issued on the 7th of March 2005. There shall be no discharge under the terms of this consent until the 31st of March 2010 or the end of commissioning of the works whichever is sooner. The Consent Holder shall give the Environment Agency at least 28 days written notice before making the discharge.

ANNEX 1

Plan BP0034002

