

Schedule 1 – 5.1.1 Notification

PART A

Permit Number:	BR9715IB
Name of Operator:	Solutia UK Ltd
Location of Installation:	Corporation Road, Newport, Gwent, NP194XF
Location of the emission:	Boiler 16 [Permit Ref: A4]
Time and date of the emission:	20/11/2018

Substance(s) emitted	Media e.g. air /water	Best estimate of the quantity or the rate of emission	Time during which the emission took place
Oxides of Nitrogen	Emission to atmosphere	Estimated concentration ~200mg/Nm3	See below

Measures taken, or intended to be taken, to stop the emission:	<p>The Gas Turbine unit attached to Boiler 16 has temporarily ceased operation due to a failure of the associated Gas Compressor unit. Due to the mode of failure, the unit is not serviceable on site, and has to be returned to the manufacturer for: assessment, refurbishment / replacement</p> <p>Emissions will revert to pre-GT operation until such time that operation can be resumed</p>
---	--

* Signed: 

Date: 21/11/2018

* authorised to sign on behalf of Solutia UK Ltd