

Schedule 5 - Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

Part A

Permit Number	EPR/EP3738NG
Name of operator	WEPA UK Ltd
Location of Facility	Bridgend Paper Mill
Time and date of the detection	14/07/2022

(a) Notification requirements for any activity that gives rise to an incident or accident which significantly affects or may significantly affect the environment	
To be notified Immediately	
Date and time of the event	14/07/2022
Reference or description of the location of the event	Effluent treatment plant - final settlement tank (FST)
Description of where any release into the environment took place	W1 - No release outside of permit limits to date Alternative clarifier (no.6) being utilised as a final settlement tank to ensure continued discharge within limits.
Substances(s) potentially released	No substances released to date outside of permit limits. Risk of alternative control measure using no.6 clarifier providing out of consent discharge. If out of consent discharge water is produced it will be fully recycled within site.
Best estimate of the quantity or rate of release of substances	n/a
Measures taken, or intended to be taken, to stop any emission	Final settlement tank maintenance required to bring back to OEM standards. Use of alternative clarifier to act as final settlement tank to maintain a controlled discharge
Description of the failure or accident.	Final settlement tank main bridge came out of alignment. Tank needs to be emptied in order to repair any damage. Downtime also to be utilised to conduct planned maintenance to other areas at the same time.

(b) Notification requirements for the breach of a permit condition	
To be notified immediately	
Emission point reference/ source	
Parameter(s)	
Limit	
Measured value and uncertainty	
Date and time of monitoring	
Measures taken, or intended to be taken, to stop the emission	

Time periods for notification following detection of a breach of a limit	
Parameter	Notification period

(c) In the event of a breach of permit condition which poses an immediate danger to human health or threatens to cause an immediate significant adverse effect on the environment:	
To be notified immediately	
Description of where the effect on the environment was detected	
Substances(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

Part B - to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	
Measures taken, or intended to be taken, to prevent a recurrence of the incident	
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	
The dates of any unauthorised emissions from the facility in the preceding 24 months.	

Name*	Richard Lewis
Post	Energy & Environment Manager
Signature	<i>RLewis</i>
Date	15/07/2022

* authorised to sign on behalf of the operator