

RELEASES TO AIR
RETURN OF DISCONTINUOUS MONITORING RESULTS
 Location: Barry Power Station Form:
 Permit/Variation Number: JP3333LV/V0004

IED PM1

Year: 2018	LCP 43				
Six months to Jul - Dec					
Measurement approach	NO _x	SO ₂	CO	Hg	Dust
Time					
Date					
Measurement 1 (mg/m ³) ^(b)					
Measurement 2 (mg/m ³) ^(b)					
Measurement 3 (mg/m ³) ^(b)					
Alternative approach ^(c)					
Method ^(d)		FS			DF
Calculation (mg/m ³)		0.243			0
Operational data ^(a)					
Load (%MCR)					
Fuel 1 name (%)					
Fuel 2 name (%)					
Fuel 3 name (%)					
Daily Emission Limit Value					
(mg/m ³)					

NOTES:

- (a) Operational data for the test period (measurement approach) or the six month period to date (Alternative approach)
- (b) Reference conditions for mg/m³ are 15% O₂ CCGT, 6% O₂ solid fuels, 3% O₂ for oil and gas, dry, 0°C, 101.325 kPa
- (c) Alternative approach to discontinuous monitoring by agreement with the Competent Authority
- (d) Use abbreviation: NF for agreed NO_x factor, FS for fuel sulphur content, CS for agreed CO factor, DF for agreed dust factor

Signed on behalf of the Operator by:

A. MacLisken.....

Date of return:

14 Jan 19.....