

Permit Number: JP3333LV/V0004

Operator: Centrica Barry Limited

Installation: Barry Power Station Form Number: Water1: 28/03/07

Reporting of emissions to water (other than to sewer) for the period from 01/010/2018 to 31/12/2018

Emission Point	Substance / Parameter	Emission Limit Value	Reference Period	Result [1]	Test Method [2]	Sample Date and Times [3]	Uncertainty [4]
W1	Oil and grease	No visible emission	Spot sample	None	Visual inspection	21 st Oct 2018	-
W1	Oil and grease	No visible emission	Spot sample	None	Visual inspection	25 th Nov 2018	-
W1	Oil and grease	No visible emission	Spot sample	None	Visual inspection	23 rd Dec 2018	-
W1	pH	6 - 9	Spot sample	7.80	BS 6068- 2.50:1995, ISO 10523:1994 or other ISO, BS or SCA blue book method as approved by the Environment Agency.	21 st Oct 2018	-
W1	pH	6 - 9	Spot sample	6.99	BS 6068- 2.50:1995, ISO 10523:1994 or other ISO, BS or SCA blue book method as approved by the Environment Agency.	25 th Nov 2018	-
W1	pH	6 - 9	Spot sample	7.15	BS 6068- 2.50:1995, ISO 10523:1994 or other ISO, BS or SCA blue book method as approved by the Environment Agency.	23 rd Dec 2018	-

- [1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum - maximum' measured values.
- [2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, e.g. gas chromatography.
- [3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.
- [4] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

Signed A. Madhison Date 19
 (Authorised to sign as representative of Operator)