

CONSENT NO.	CG0351301
--------------------	-----------



WATER RESOURCES ACT 1991

SECTION 88 - SCHEDULE 10

(AS AMENDED BY THE ENVIRONMENT ACT 1995)

NOTICE OF MODIFICATION OF CONSENT TO DISCHARGE

TO: Dŵr Cymru Cyfyngedig (“the Consent Holder”)
c/o Environment Quality Scientist
Pentwyn Road
Nelson
Treharris
CF46 6LY

Following a review of the conditions of its consent, the **ENVIRONMENT AGENCY** ("the Agency") in pursuance of its powers under the Water Resources Act 1991 **HEREBY MODIFIES ITS CONSENT** to the making of a discharge **OF SEWAGE EFFLUENT**, as follows:

Storm Sewage or Sewage discharge in an emergency

with respect to Consent No. CG0351301 issued on the 21st day of October 1994.

FROM: Aberdyfi Wharf Sewage Pumping Station

AT: SN 61530 95950

TO: Afon Dyfi

FROM NOW ON the consent is modified as followed:

A. Addition of the following new conditions 9 and 10 to Schedule 01:

9. (a) The combined sewer overflow shall be designed to ensure that there shall be no more than 3 spills per bathing season (i.e. May to September inclusive) on average over a ten year period.

A spill is defined as follows:

One or more overflow events of total volume greater than 50m³/d within a period of 12 hours or less will be considered to be one spill. One or more of such overflow events (extending over a period of greater than 12 hours up to 36 hours will be considered to be 2 spills. Each subsequent 24 hour duration of such overflow events counts as 1 additional spill.

- (b) The combined sewer overflow shall be constructed and operated in accordance with the design


- (c) At the request of the Agency, the Consent Holder shall provide calculations and evidence to confirm that the combined sewer overflow is designed and constructed in accordance with conditions (a) and (b) above.
10. (a) A recording system shall be provided and maintained to record the frequency and duration of overflow events.
- (b) The Consent Holder shall supply the Environment Agency, with an annual written report of the operation of the combined sewer overflow, to include date, start time and duration of each spill in accordance with the format provided by the Environment Agency.
- (c) Provision of this report will coincide with the annual monitoring under the Bathing Water Directive. The report shall cover the 5 month period 1st May–30th September inclusive, and shall be provided by the end of October.
- (d) On request, the Consent Holder shall supply the Environment Agency with written details of individual spill event(s).

NOTE. All other conditions of this consent remain unaltered and in force. This modification of consent should be read in conjunction with, and attached to Schedule 01 of Consent No. CG0351301.

Under the provisions of Paragraphs 7 and 8 of Schedule 10 to the Water Resources Act 1991, no notice shall be served by the Agency, which alters the effect of modifications made by this notice, without the agreement in writing of the Consent Holder, during a period of 4 years from the date this notice is served.

This modification is served on 31st day of March 2010

This modification takes effect on 31st day of March 2012



Signed

Christopher Hall
Team Leader – National Permitting