

Permit Reference Number: BL3986ID

Installation: Aberthaw Works

Operator: Tarmac Cement & Lime Ltd

Form Number: Water 1 / 19/07/16

Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2
for the period 01/10/18 to 31/8/18 31/10/18 *Edm.*

Emission Point	Parameter	Emission Limit Value	Result	Date of Measurement	Method
W1	pH (minimum)	6	8.2	22.10.2018	BS ISO10523
W1	pH (maximum)	9	-	-	BS ISO10523
W1	Total Suspended Solids (Maximum)	50 mg/l	10.0 mg/l	22.10.2018	BS EN 872
W1	Oil or Grease	None Present	None Visible	22.10.2018	Visual Check
W2	pH (minimum)	6	-	-	BS ISO10523
W2	pH (maximum)	9	-	-	BS ISO10523
W2	Total Suspended Solids (Maximum)	50 mg/l	-	-	BS EN 872
W2	Oil or Grease	None Present	-	-	Visual Check

Signed : K. Bennett
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

Date :30.01.2019

Permit Reference Number: BL3986iD

Operator: Tarmac Cement & Lime Ltd

Installation: Aberthaw Works

Form Number: Water 1 / 19/07/16

**Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2
for the period 01/11/18 to 30/11/18**

Emission Point	Parameter	Emission Limit Value	Result	Date of Measurement	Method
W1	pH (minimum)	6	7.9	15.11.2018	BS ISO10523
W1	pH (maximum)	9	-	-	BS ISO10523
W1	Total Suspended Solids (Maximum)	50 mg/l	13 mg/l	15.11.2018	BS EN 872
W1	Oil or Grease	None Present	None Visible	15.11.2018	Visual Check
W2	pH (minimum)	6	-	-	BS ISO10523
W2	pH (maximum)	9	-	-	BS ISO10523
W2	Total Suspended Solids (Maximum)	50 mg/l	-	-	BS EN 872
W2	Oil or Grease	None Present	-	-	Visual Check

Signed : K. Bennett
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

Date :29.01.2019

Permit Reference Number: BL3986iD

Operator: Tarmac Cement & Lime Ltd

Installation: Aberthaw Works

Form Number: Water 1 / 19/07/16

**Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2
for the period 01/12/18 to 31/12/18**

Emission Point	Parameter	Emission Limit Value	Result	Date of Measurement	Method
W1	pH (minimum)	6	7.7	19.12.2018	BS ISO10523
W1	pH (maximum)	9	-	-	BS ISO10523
W1	Total Suspended Solids (Maximum)	50 mg/l	20 mg/l	19.12.2018	BS EN 872
W1	Oil or Grease	None Present	None Visible	19.12.2018	Visual Check
W2	pH (minimum)	6	-	-	BS ISO10523
W2	pH (maximum)	9	-	-	BS ISO10523
W2	Total Suspended Solids (Maximum)	50 mg/l	-	-	BS EN 872
W2	Oil or Grease	None Present	-	-	Visual Check

Signed : K. Bennett
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

Date :29.01.2019