

Notice of request for more information

Environmental Permitting (England and Wales)
Regulations 2016

Notice requiring further information

To:

Dŵr Cymru Cyfyngedig
Dwr Cymru Welsh Water Linea
Fortran Road
St. Mellons
Cardiff
Wales
CF3 0LT

Application number: PAN-018778 (EPR/ZP3032KQ)

Natural Resources Wales, in exercise of its powers under paragraph 4 of Part 1 of Schedule 5 of the above Regulations, requires you to provide the information detailed in the attached schedule. The information is required in order to determine your application for a permit, dated 29/09/2022. The information requested should be sent to the following address by **27/04/2023**.

Information should be sent to:

Wales Permitting Centre
Natural Resources Wales
Cambria House
29 Newport Road
Cardiff
CF24 0TP

| Name | Date |
|---------------------|-------------------|
| Lucinda Hall | 30/03/2023 |

Authorised on behalf of Natural Resources Wales

Schedule

The notice specifies what you need to send and when you must send it by. If we do not receive it by the date set out in the notice, then we may treat your application as having been withdrawn.

1. CIRIA Risk Assessment – Secondary Containment for Site

Submit revised CIRIA Risk Assessment(s) which demonstrate compliance against BAT19 of the Waste Treatment BREF BAT Conclusions (2018).

Note. The CIRIA Risk Assessments submitted within your application divide the site into zones. It is unclear from the documentation submitted, what the total storage volume is for the site is, and whether containment capacity required is greater than 110 percent of the largest tank or 25 percent of the total storage volume across all zones, or how the containment solution meets BAT19. Drainage plans submitted do not currently show the location of soft landscaping around the north of the site which is referred to within your proposed solution. The assessment does not clearly define how appropriate secondary containment could be achieved utilising existing engineered infrastructure within the wider footprint of the WwTW, and what, if any, additional mitigation measures would be in place to minimise loss of containment.