

CONSENT NO.	BG0013202
--------------------	------------------

WATER RESOURCES ACT 1991

SECTION 88 - SCHEDULE 10

(AS AMENDED BY THE ENVIRONMENT ACT 1995)

VARIATION OF CONSENT TO DISCHARGE

TO: Dŵr Cymru Cyfyngedig ("the Consent Holder")
C/O Environment Quality Scientist
Pentwyn Road
Nelson
Treharris
CF46 6LY

In pursuance of an application by the consent holder for variation of consent, the **ENVIRONMENT AGENCY** ("The Agency") in pursuance of its powers under the Water Resources Act 1991 **HEREBY VARIES ITS CONSENT** to the making of a discharge **OF SEWAGE EFFLUENT**, as follows:

Storm Sewage

with respect to modification of Consent No. **BG0013202** served on 24th March 2005

FROM: A Combined Sewer Overflow.

AT: Llanddewi Velfrey WwTw

TO: A tributary of Pont-Shan Brook

SUBJECT TO the conditions set out in the following schedule:


Storm Sewage:

Schedule No. BG0013202 01

Subject to the provisions of Paragraphs 7 and 8 of Schedule 10 of the Water Resources Act 1991, no notice shall be served by the Agency, which alters the effect of variations made to this consent, without the agreement in writing of the consent holder, during a period of 4 years from the date this variation is issued.

This variation of consent is issued on the 24th day of April 2009

This variation of consent takes effect on the 31st day of March 2010



Signed

Christopher Hall - National Permitting Team Leader

CONSENT NO.	BG0013202
SCHEDULE NO.	BG0013202 01
DATE ISSUED	24/04/09

CONDITIONS OF CONSENT TO DISCHARGE

Storm Sewage (“the Discharge”)

FROM: A Combined Sewer Overflow, Llanddewi Velfrey WwTw

NATURE

1. The Discharge shall consist solely of storm sewage.

LOCATION

2. The Discharge shall be made in the manner and at the place specified as:
 - (a) discharging via a 150 mm diameter pipe;
 - (b) discharging to a tributary of Pont-Shan Brook;
 - (c) at National Grid Reference SN 14234 16819;
 - (d) shown marked 'Consent Point' on Plan BG0013202 attached as Annex 1.

SAMPLE POINT

3. A sample point shall be provided and maintained at National Grid Reference SN 14229 16871 as shown marked ‘Sample Point’ on Plan BG0013202, so that a representative sample of the Discharge may be obtained. The Consent Holder shall ensure that all constituents of the Discharge pass through the said sampling point at all times and in any legal proceedings it shall, for the purposes of Section 10 of the Rivers (Prevention of Pollution) Act 1961, be presumed, until the contrary is shown that any sample of the Discharge taken at the said sampling point is a sample of what was discharging into controlled waters.

VOLUME

4. The Discharge shall occur when the rate of flow in the sewer at the combined sewage overflow exceeds 4.3 litres per second due to rainfall and/or snow melt and shall consist only of flows in excess of this figure.

COMPOSITION

5.
 - (a) The Discharge shall have passed, without prior comminution or maceration, through a screening device having apertures no greater than 6 millimetres in two dimensions.
 - (b) The screening device shall be maintained in an efficient operational condition.
 - (c) All screenings must be removed and disposed of in a manner such as to prevent entry to the discharge.

CONSENT NO.	BG0013202
SCHEDULE NO.	BG0013202 01

MAINTENANCE

6. The overflow shall be maintained in an efficient operational condition.

TELEMETRY

7. (a) A 24 hour response telemetry alarm system shall be provided by start of commissioning of the overflow.
- (b) The 24 hour response telemetry alarm shall be maintained to provide a notification in the event of a failure of the screen raking mechanism during normal operation.
- (c) The Consent Holder shall notify the agency, at least within 24 hours after receipt of a telemetry warning, that the failure has taken place.
- (d) On request the Consent Holder shall supply the agency with a written report on the screen raking mechanism failure. The report shall detail the reasons why the situation occurred, the actions taken by the Consent holder and an assessment of what measures can be adopted in the future to minimise such occurrences.

START DATE

8. Until discharge is permitted under the terms of this consent, the quality of the effluent from the Combined Sewer Overflow, Llanddewi Velfrey WwTw shall be controlled under the terms of the Consent issued on 11th May 1993. There shall be no discharge under the terms of this consent until the 31st March 2010 or the end of commissioning of the combined sewer overflow which ever is the sooner. The Consent Holder shall give the Environment Agency at least 28 days written notice before making the discharge.

Annex1

Plan BG0013202



(H) Hawlfraint y Goron. Cedwir pob hawl. Asiantaeth yr Amgylchedd, 100026380, 2008.

© Crown Copyright. All rights reserved. Environment Agency, 100026380, 2008.