

Our Ref: COLINS 12175
Your Ref:

Derwent Renewable Power Ltd.,
Argoed Farm,
Trefeglwys,
Caersws,
Newtown,
Powys
SY17 5QT

Company Number: 09714157

4 April 2023

Dear Sir / Madam

Re: Argoed Farm AD Plant, Trefeglwys, Powys

On 13th July 2022 Natural Resources Wales carried out a site visit to the above site to assess compliance with the Environmental Permit EPR-AB3090CC. During the visit it was identified and then recorded on Compliance Report (ref: CAR_NRW0040131), that there were Compliance Classification System (CCS) Category 2 breaches of permit conditions: 2.4.1 - Site drainage engineering (clean and foul); 1.1.1 - Management system and operating procedures and 3.2.1 - Emissions to Surface water.

These breached all related to the reasonably foreseeable risk of pollution to surface water, due to your failure to ensure that clean and dirty drainage was kept separate. It is your responsibility to ensure that you operate the above site in accordance with the conditions of the permit.

The enclosed Warning Letter is NRW's enforcement response regarding this matter. If you have any queries regarding the contents of this letter, my contact details are below.

Yours faithfully.



Malcolm Dines
Waste Regulation Officer

Tel: 03000653403

Direct e-mail: Malcolm.dines@cyfoethnaturiolcymru.gov.uk

Address: Welsh Government Offices, Rhodfa Padarn, Llanbadarn Fawr, Ceredigion, SY23 3UR

Croesewir gohebiaeth yn y Gymraeg a'r Saesneg
Correspondence welcomed in Welsh and English