

Permit Number: EPR/VP3736EF
Operator: The BOC Group Limited
Facility: Newport Steam Reforming Plant
Reporting: 4.2.2(a)

01/01/18 – 31/12/18

Reviewing the performance monitoring data for the installation for the given reporting period, the results are:

- Within the reporting limits for all parameters.

Work followed on from 2017 into 2018 to improve the steam raising efficiency, optimise its usage and to increase the minimum turn down of the plant. This has led to a reduction in NOx emissions (59.5mgm^{-3}) which is well within the limit value of 140mgm^{-3} .

There has been an increase in the hydrogen produced due to customer demand and improved plant reliability.

R Warren (SHEQ Manager Margam and Satellites)

25/01/2019