

Permit Number: EA/EPR/BK3638IF/V002

Operator: Hydro Aluminium Limited

Facility: Wrexham Aluminium Works

Form Number: Water1

Reporting of emissions to water (other than to sewer) and land for the period from 01/01/2021 to 31/03/2021

Emission Point	Substance / Parameter	Emission Limit Value	Reference Period	Result	Test Method	Sample Date and Times	Uncertainty
W1	BOD	10 mg/l	Single sample	-	-	-	-
W1	Suspended Solids	35 mg/l	Single sample	-	-	-	-
W1	pH	6 – 9	Single sample	-	-	-	-
W1	COD	125 mg/l	Single sample	-	-	-	-
W1	Ammoniacal Nitrogen	5 mg /l	Single sample	-	-	-	-
W1	Aluminium	0.5 mg/l	Single sample	-	-	-	-
W1	Total Hydrocarbon Oil	2 mg/l	Single sample	-	-	-	-
W1	Temperature	25 °C	Single sample	-	-	-	-
W1	Flow	N/A	-	-	-	-	-

Note: "Nil Return" submitted following on-site discussion with the Environment Agency on 14th June 2012. There were no discharges to W1 that required a sample to be taken in January – March 2021.

SignedJoel Priest.....
(Authorised to sign as representative of Operator)

Date28/04/2021.....

Results have been corrected as per condition 3.1.4.