

SCHEDULE 5 Notification	
Part A	
Permit Number:	BL7108IM
Name of Operator:	Tata Steel UK Ltd
Location of Facility:	Port Talbot Works
Time & Date of the Detection	01/03/2021 08:00am

(b) Notification requirements for breach of a permit condition	
Emission point/reference source	A50 Service Boiler 4 & 5 Stack
Parameter(s)	SO ₂
Limit	Daily fuel-weighted dynamic emission limits 12 February at 161.7mg/m ³ vs daily FWL of 156.5 mg/m ³ .
	12 th February: 161.7mg/m ³ 95% confidence level has already been subtracted from measured hourly average results – permit condition 3.6.7 (a)
Date and time of monitoring	Daily means from continuous emission monitoring 12 th February 2021: 00:00 to 23:59
Measures taken, or intended to be taken, to stop the emission	No abatement of SO ₂ emissions from boiler stacks. SO ₂ emissions in boiler flue gas due to H ₂ S content of Coke Oven Gas – currently no desulphurisation process in place as per permit derogation.
REF: S5N/22/16A	