

SCHEDULE 5 Notification	
Part A	
Permit Number:	BL7108IM
Name of Operator:	Tata Steel UK Ltd
Location of Facility:	Port Talbot Works
Time & Date of the Detection	07/03/22@ 09:00

(b) Notification requirements for breach of a permit condition				
Emission point/reference source	A1 Sinter Main			
Parameter(s)	Particulate			
Limit	40mg/m3			
Measured value and uncertainty	See below (+ / - 30%)			
Date and time of monitoring	01-Feb-22	57.28	Duel Fan	
	02-Feb-22	49.03	Duel Fan	
	04-Feb-22	43.93	Duel Fan	
	05-Feb-22	46.19	Duel Fan	
	07-Feb-22	51.97	Duel Fan	
	08-Feb-22	44.44	Duel Fan	
	09-Feb-22	57.83	Duel Fan	
	11-Feb-22	76.55	Single Fan	
	12-Feb-22	67.48	Single Fan	
	13-Feb-22	40.73	Single Fan	
	14-Feb-22	50.50	Single Fan	
	16-Feb-22	41.82	Single Fan	
	20-Feb-22	42.39	Single Fan	
	25-Feb-22	45.81	Single Fan	
	28-Feb-22	47.30	Single Fan	
Measures taken, or intended to be taken, to stop the emission	Sinter Plant emission reduction programme in place			
REF: S5N/22/18A				