

| <b>SCHEDULE 5 Notification</b> |                   |
|--------------------------------|-------------------|
| <b>Part A</b>                  |                   |
| Permit Number:                 | BL7108IM          |
| Name of Operator:              | Tata Steel UK Ltd |
| Location of Facility:          | Port Talbot Works |
| Time & Date of the Detection   | 01/04/2022 08:00  |

| <b>(b) Notification requirements for breach of a permit condition</b> |                                                                                                                                                                                                                                               |
|-----------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Emission point/reference source                                       | A50 Service Boiler 4 & 5 Stack                                                                                                                                                                                                                |
| Parameter(s)                                                          | SO <sub>2</sub>                                                                                                                                                                                                                               |
| Limit                                                                 | Daily fuel-weighted dynamic emission limits<br><br>31 March at 473.5mg/m <sup>3</sup> vs daily FWL of 237.4 mg/m <sup>3</sup> .                                                                                                               |
|                                                                       | 12 <sup>th</sup> February: 473.5mg/m <sup>3</sup><br><br>95% confidence level has already been subtracted from measured hourly average results – permit condition 3.6.7 (a)                                                                   |
| Date and time of monitoring                                           | Daily means from continuous emission monitoring<br><br>31 <sup>st</sup> March 2022: 00:00 to 23:59                                                                                                                                            |
| Measures taken, or intended to be taken, to stop the emission         | No abatement of SO <sub>2</sub> emissions from boiler stacks.<br><br>SO <sub>2</sub> emissions in boiler flue gas due to H <sub>2</sub> S content of Coke Oven Gas – currently no desulphurisation process in place as per permit derogation. |
| <b>REF: S5N/22/34A</b>                                                |                                                                                                                                                                                                                                               |