

SCHEDULE 5 Notification	
Part A	
Permit Number:	BL7108IM
Name of Operator:	Tata Steel UK Ltd
Location of Facility:	Port Talbot Works
Time & Date of the Detection	01/05/2022 08:00am

(b) Notification requirements for breach of a permit condition	
Emission point/reference source	A50 Service Boiler 4 & 5 Stack
Parameter(s)	SO ₂
Limit	Daily fuel-weighted dynamic emission limits 1st April: 330 mg/m³ vs daily limit of 232 mg/m³ 8th April: 377 mg/m³ vs daily limit of 281 mg/m³ 13th April: 259 mg/m³ vs daily limit of 211 mg/m³ 22nd April: 259 mg/m³ vs daily limit of 233 mg/m³
	95% confidence level has already been subtracted from measured hourly average results – permit condition 3.6.7 (a)
Date and time of monitoring	Daily means from continuous emission monitoring 1st April 2022: 00:00 to 23:59 8th April 2022: 00:00 to 23:59 13th April 2022: 00:00 to 23:59 22nd April 2022: 00:00 to 23:59
Measures taken, or intended to be taken, to stop the emission	No abatement of SO₂ emissions from boiler stacks. SO₂ emissions in boiler flue gas due to H₂S content of Coke Oven Gas – currently no desulphurisation process in place as per permit derogation.
REF: S5N/22/37A	