

### SCHEDULE 5 Notification

**Part A**

Permit Number:	BL7108IM
Name of Operator:	Tata Steel UK Ltd
Location of Facility:	Port Talbot Works
Time & Date of the Detection	10/05/2022; 8:00am

**(b) Notification requirements for breach of a permit condition**

Emission point/reference source	W5 Cooling Water Discharge into Port Talbot Dock
Parameter(s)	Suspended Solids
Limit	20 mg/l (shall not exceed background concentration by the figure indicated)
Measured value and uncertainty	Measured Result Cold = 12 mg/l. Measured Result 3TA = 38 mg/l. 3TA result = 26 mg/l above background level. Monitoring uncertainty value = 5.9 mg/l based on a difference of 26 mg/l between the two samples.
Date time of monitoring, and emission value.	Date time of monitoring = 28/04/2022 Adjusted difference between the two samples following the application of uncertainty = 20.1 mg/l.
Measures taken, or intended to be taken, to stop the emission	Investigations are ongoing as to the cause of the breach.

**REF: S5N/22/41A**