

Date of form 13/10/14

Date of form 13/10/14

NOT YET COMMISSIONED

Date of form 13/10/14

Schedule 3 - Form Number: A3

Operator: Kepak

Permit Number: AP3433ES

Installation: Dowlais Slaughterhouse

Release to Air

Release Point: A2

Release for Quarter ending: December 2022

NIL RETURNED

Reporting Form A3			
Details of operation of by-pass stack			
Date	Time	Duration	Reason for Operation

Signed on behalf of the Operator



Date ...04/01/2023.....

Schedule 3 - Form Number: W1

Operator: Kepak

Permit Number: AP3433ES

Installation: Dowlais Slaughterhouse

Release to Water

Release Point: W1, W2

Release for Quarter ending: [December 2022](#)

Reporting Form W1				
Parameter	Limit Value	Release Point W1	Release Point W2	Month and Date
Mineral oil and hydrocarbons mg/l	5	0.6	0.6	6/10/2022
Suspended Solids mg/l	50	2	2	6/10/2022
Mineral oil and hydrocarbons mg/l	5	0.6	0.6	2/11/2022
Suspended Solids mg/l	50	3	2	2/11/2022
Mineral oil and hydrocarbons mg/l	5	0.76	0.6	1/12/2022
Suspended Solids mg/l	50	6	10	1/12/2022

Signed on behalf of the Operator

Date04/01/2023.....



Schedule 3 - Form Number: S1**Operator: Kepak****Permit Number: AP3433ES**

Installation: Dowlais Slaughterhouse

Release to Sewer

Release Point: S1

Release for Quarter ending: **December 2022**

Reporting Form S1					
Parameter	Limit Value(s)	Min	Average	95 th Percentile Value	Maximum
pH	6<x<11	6.2	7.7	9.34	9.4
Total suspended solids mg/l	600	21	49.2	96.4	115
Total chemical oxygen demand (COD) mg/l	3600	179	394.5	592.4	695
Free or emulsified grease or oil mg/l	100	2.31	12.5	27.68	32.6
Anionic synthetic detergent as manoxol OT mg/l	100	0.025	0.0	0.03	0.025
Dissolved oxygen mg/l	-	0.5	1.0	3.1	6.7
Ammoniacal nitrogen as N mg/l	-	5.88	21.3	38.84	57.5
Daily flow m ³ /day	800	36.7	557.6	782.4	797.5
Maximum flow m ³ /h	34	1.5	23.2	32.6	33.2

Signed on behalf of the Operator



Date04/01/2023.....