

Schedule 1 - Notification of abnormal emissions

This page outlines the information that the Operator must provide to satisfy conditions 5.1.1 and 5.1.2 of this Permit.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the PPC Regulations.

Part A

Permit Number	AP3433ES
Name of Operator	Kepak Group Ltd
Location of Installation	Merthyr Tydfil
Location of the emission	Pack HT5
Time and date of the emission	22/05/21

Substance(s) emitted	Media	Best estimate of the quantity or the rate of emission	Time during which the emission took place
R404AR	Air Emission	312 Kg	22/05/2021

Measures taken, or intended to be taken, to stop the emission	Continuation of undertaking of leak detection work and planned maintenance of refrigeration units.
---	--

Part B

Any more accurate information on the matters for notification under Part A.	System topped up after previous leaks on condenser and recovery heat exchanger were repaired.162.2 KG topped up so far potentially a further 150kg to be added if required
Measures taken, or intended to be taken, to prevent a recurrence of the incident	Continuation of undertaking of leak detection work and planned maintenance of refrigeration units.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission	

The dates of any unauthorised emissions from the installation in the preceding 24 months.	23/12/20 W2 Surface water (Run off from scrapyard) 02/04/20- W1 Emission of Suspended Solids 02/04/20- W1 Emission of Mineral oil and hydrocarbon 15/03/20- Emissions to Air refrigerant -R404A & R448A 31/01/2020- W1 and W2 sample not taken for January 02/02/2020- Emissions to Air refrigerant R404A 02/02/20- S1 - Emission exceedance-SS 02/02/20- S1 - Emission exceedance- COD 02/01/20- S1 - Emission exceedance-Oils & Grease 01/12/19- Emissions to Air refrigerant-R448A 06/10/19- Emissions to Air refrigerant -R404A
---	---

Name*	Paul Williams
Post	Assistant Tech Manager
Signature	
Date	28/06/21

* authorised to sign on behalf of 2 Sisters Red Meat Ltd