

Date of form 13/10/14

Date of form 13/10/14

NIL RETURNED

[illegible]

Signed on behalf of the Operator

Date ...08/11/2022.....

Schedule 3 - Form Number: W1

Operator: Kepak

Permit Number: AP3433ES

Installation: Dowlais Slaughterhouse

Release to Water

Release Point: W1, W2

Release for Quarter ending: September 2022

Reporting Form W1				
Parameter	Limit Value	Release Point W1	Release Point W2	Month and Date
Mineral oil and hydrocarbons mg/l	5	0.6	0.6	27/07/2022
Suspended Solids mg/l	50	8	4	27/07/2022
Mineral oil and hydrocarbons mg/l	5	0.6	0.6	04/08/2022
Suspended Solids mg/l	50	7	4	04/08/2022
Mineral oil and hydrocarbons mg/l	5	0.92	0.96	08/09/2022
Suspended Solids mg/l	50	20	36	08/09/2022

Signed on behalf of the Operator



Date08/11/22.....

Schedule 3 - Form Number: S1**Operator: Kepak****Permit Number: AP3433ES**

Installation: Dowlais Slaughterhouse

Release to Sewer

Release Point: S1

Release for Quarter ending: September 2022

Reporting Form S1					
Parameter	Limit Value(s)	Min	Average	95 th Percentile Value	Maximum
pH	$6 < x < 11$	6.2	7.5	9.72	10.2
Total suspended solids mg/l	600	17	43.8	82.2	93
Total chemical oxygen demand (COD) mg/l	3600	43	220.3	335.8	346
Free or emulsified grease or oil mg/l	100	4.73	9.6	15.82	20.8
Anionic synthetic detergent as manoxol OT mg/l	100	0.025	0.0	0.03	0.025
Dissolved oxygen mg/l	-	0.5	1.0	3.4	7.3
Ammoniacal nitrogen as N mg/l	30	4.98	10.9	16.22	20
Daily flow m ³ /day	800	43.7	548.8	800.6	810.9
Maximum flow m ³ /h	34	1.8	22.9	33.4	33.8

Signed on behalf of the Operator



Date08/11/22.....