

Date of form 13/10/14

Date of form 13/10/14

Schedule 3 - Form Number: A3

Operator: Kepak

Permit Number: AP3433ES

Installation: Dowlais Slaughterhouse

Release to Air

Release Point: A2

Release for Quarter ending: March 2022

NIL RETURNED

Reporting Form A3			
Details of operation of by-pass stack			
Date	Time	Duration	Reason for Operation

Signed on behalf of the Operator



Date ... 07.04.22

Permit EPR/AP3433ES

Date of form 13/10/14

Schedule 3 - Form Number: W1

Operator: Kepak

Permit Number: AP3433ES

Installation: Dowlais Slaughterhouse


Release to Water

Release Point: W1, W2

Release for Quarter ending: March2022

Reporting Form W1				
Parameter	Limit Value	Release Point W1	Release Point W2	Month and Date
Mineral oil and hydrocarbons mg/l	5	0.6	0.6	06/01/2022
Suspended Solids mg/l	50	4	6	06/01/2022
Mineral oil and hydrocarbons mg/l	5	0.6	0.6	25/02/202
Suspended Solids mg/l	50	4	2	25/02/2022
Mineral oil and hydrocarbons mg/l	5	0.6	0.6	10/03/2022
Suspended Solids mg/l	50	25	12	10/03/2022

Signed on behalf of the Operator



Date ...07/04/22.....

Permit EPR/AP3433ES

Date of form 13/10/14

Schedule 3 - Form Number: S1

Operator: Kepak

Permit Number: AP3433ES

Installation: Dowlais Slaughterhouse


Release to Sewer

Release Point: S1

Release for Quarter ending: March 2022

Reporting Form S1					
Parameter	Limit Value(s)	Min	Average	95 th Percentile Value	Maximum
pH	6-11	6.4	7.5	9.3	9.7
Total suspended solids mg/l	600	12	40.0	67	90
Total chemical oxygen demand (COD) mg/l	3600	26	290.08	425	646
Free or emulsified grease or oil mg/l	100	0.6	8.7	19.76	20.9
Anionic synthetic detergent as manoxol OT mg/l	100	0.025	0.025	0.025	0.025
Dissolved oxygen mg/l	-	0.5	1.6	7.62	8.7
Ammoniacal nitrogen as N mg/l	30	0.41	8.8	18.88	28
Daily flow m ³ /day	800	47.8	570.7	781.7	797.5
Maximum flow m ³ /h	34	2.0	23.8	32.6	33.2

Signed on behalf of the Operator



Date 07/04/22

Permit EPR/AP3433ES

Date of form 13/10/14