

Date of form 13/10/14

Date of form 13/10/14

Date of form 13/10/14

NIL RETURNED

[illegible]

L. C. M.

Date ... 15/07/2022.....

Permit EPR/AP3433ES

Date of form 13/10/14

Schedule 3 - Form Number: W1

Operator: Kepak

Permit Number: AP3433ES

Installation: Dowlais Slaughterhouse

Release to Water

Release Point: W1, W2

Release for Quarter ending: June 2022

Reporting Form W1				
Parameter	Limit Value	Release Point W1	Release Point W2	Month and Date
Mineral oil and hydrocarbons mg/l	5	0.7	0.6	07/04/2022
Suspended Solids mg/l	50	12	1	07/04/2022
Mineral oil and hydrocarbons mg/l	5	0.6	5	05/05/2022
Suspended Solids mg/l	50	4.72	19	05/05/2022
Mineral oil and hydrocarbons mg/l	5	7.47	1.6	02/06/2022
Suspended Solids mg/l	50	21	2	02/06/2022

Signed on behalf of the Operator

Date 15/07/22.....

Permit EPR/AP3433ES

Date of form 13/10/14

Schedule 3 - Form Number: S1

Operator: Kepak

Permit Number: AP3433ES

Installation: Dowlais Slaughterhouse

Release to Sewer

Release Point: S1

Release for Quarter ending: June 2022

Reporting Form S1					
Parameter	Limit Value(s)	Min	Average	95 th Percentile Value	Maximum
pH	6<x<11	6.4	7.9	9.94	10.3
Total suspended solids mg/l	600	8	53.0	84.6	90.0
Total chemical oxygen demand (COD) mg/l	3600	148	336.1	543.4	646
Free or emulsified grease or oil mg/l	100	4.08	12.8	27.42	37.2
Anionic synthetic detergent as manoxol OT mg/l	100	0.025	0.0	0.03	0.025
Dissolved oxygen mg/l	-	0.5	0.7	1.78	3.7
Ammoniacal nitrogen as N mg/l	30	6.53	11.7	22.48	28
Daily flow m ³ /day	800	28.7	503.6	743.2	794.0
Maximum flow m ³ /h	34	1.2	21.0	31.0	33.1

Signed on behalf of the Operator

Date 15/07/22

Permit EPR/AP3433ES

Date of form 13/10/14