


SCHEDULE 5 Notification

Part B

Permit Number:	BL7108IM
Name of Operator:	Tata Steel UK Ltd
Location of Facility:	Port Talbot Works
Part A details	S5N/22/37A – Service Boiler 4 & 5 Stack

Any more accurate information on the matters notified under Part A	No further information.
Measures taken, or intended to be taken, to prevent a recurrence of the incident	<p>The SO₂ emissions in boiler flue gas are a function of the H₂S content of Coke Oven Gas (COG).</p> <p>The Large Combustion Plant Directive Annex V limits for SO₂ emissions for gaseous fuel combustion assume, in line with the Industrial Emissions Directive, that COG has been desulphurised to below 1000 mg/m³ H₂S.</p> <p>Currently, Tata is operating under a derogation from the IED H₂S limit – as such, there is no means of abatement of H₂S in COG, nor the downstream emissions where the gas is used as a fuel for the site boilers.</p>
Measures to be taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission	N/A
The dates of any Part A notifications in the previous 24 months	Please see attached Excel spreadsheet

Name*	Beverley Jenkins
Post	Lead Environmental Engineer
Signature	
Date	09/05/22
Reference	S5N 22 37B