

SCHEDULE 5 Notification																																
Part A																																
Permit Number:		BL7108IM																														
Name of Operator:		Tata Steel UK Ltd																														
Location of Facility:		Port Talbot Works																														
Time & Date of the Detection		01/02/23@ 08:00																														
(b) Notification requirements for breach of a permit condition																																
Emission point/reference source		A1 Sinter Main																														
Parameter(s)		Particulate																														
Limit		40mg/m3																														
Measured value and uncertainty		See below (+ / - 30%)																														
Date and time of monitoring		<table border="1"> <thead> <tr> <th>Date</th> <th>Measured Value (mg/m3)</th> <th>Uncertainty Applied [30%] (mg/m3)</th> <th>Fan Status</th> </tr> </thead> <tbody> <tr> <td>21-Jan-23</td> <td>65.53</td> <td>45.87</td> <td>Dual Fan</td> </tr> <tr> <td>22-Jan-23</td> <td>75.42</td> <td>52.79</td> <td>Dual Fan</td> </tr> <tr> <td>28-Jan-23</td> <td>71.38</td> <td>49.97</td> <td>Dual Fan</td> </tr> <tr> <td>29-Jan-23</td> <td>71.51</td> <td>50.06</td> <td>Dual Fan</td> </tr> <tr> <td>30-Jan-23</td> <td>77.33</td> <td>54.13</td> <td>Dual Fan</td> </tr> <tr> <td>31-Jan-23</td> <td>68.02</td> <td>47.61</td> <td>Dual Fan</td> </tr> </tbody> </table>			Date	Measured Value (mg/m3)	Uncertainty Applied [30%] (mg/m3)	Fan Status	21-Jan-23	65.53	45.87	Dual Fan	22-Jan-23	75.42	52.79	Dual Fan	28-Jan-23	71.38	49.97	Dual Fan	29-Jan-23	71.51	50.06	Dual Fan	30-Jan-23	77.33	54.13	Dual Fan	31-Jan-23	68.02	47.61	Dual Fan
Date	Measured Value (mg/m3)	Uncertainty Applied [30%] (mg/m3)	Fan Status																													
21-Jan-23	65.53	45.87	Dual Fan																													
22-Jan-23	75.42	52.79	Dual Fan																													
28-Jan-23	71.38	49.97	Dual Fan																													
29-Jan-23	71.51	50.06	Dual Fan																													
30-Jan-23	77.33	54.13	Dual Fan																													
31-Jan-23	68.02	47.61	Dual Fan																													
Measures taken, or intended to be taken, to stop the emission		Sinter Plant emission reduction programme in place																														
REF: S5N/23/10A																																