

Schedule 1 - Notification of abnormal emissions

This page outlines the information that the Operator must provide to satisfy conditions 5.1.1 and 5.1.2 of this Permit.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.


If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the PPC Regulations.

Part A

Permit Number	EPR/AP3433ES/W003		
Name of Operator	Kepak Group Ltd		
Location of installation	Merthyr Tydfil		
Location of the emission	W1		
Time and date of the emission	02/06/2022		
Substance(s) emitted	Media	Best estimate of the quantity or the rate of emission	Time during which the emission took place
Mineral Oil and Hydrocarbon	Effluent	7.23 mg/l	07:00
Measures taken, or intended to be taken, to stop the emission	Emission detected after the date of emission		

Part B

Any more accurate information on the matters for notification under Part A.	Investigation has taken place retroactively, no evidence of contamination near the sampling point (no discoloured water, foaming or thin-film interference). No incidents / spillages noted at the time of the audit and ETP plant noted to be running normally. The issue was noted to have occurred after a period of rain in late May but this is not thought to have been a sufficient downpour as to overwhelm the onsite interceptors.
Measures taken, or intended to be taken, to prevent a recurrence of the incident	Investigation conducted, monitoring to continue alongside sampling in the form of weekly environmental audits that include visual inspection of weirs.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission	No possible action available.
The dates of any unauthorised emissions from the installation in the preceding 24 months.	09/11/21 S1 - Emission exceedance - fats oils and grease. 21/07/21 S1 - Emission exceedance - fats oil and grease 22/05/21 Emissions to Air refrigerant-R404AR 16/04/21 S1 Emission exceedance - fats oil and grease 22/01/21 S1 Emission exceedance - fats oil & grease and Suspended Solids 23/12/20 W2 Surface water (Run off from scrapyard) 02/04/20- W1 Emission of Suspended Solids 02/04/20- W1 Emission of Mineral oil and hydrocarbon 15/03/20- Emissions to Air refrigerant -R404A & R448A 31/01/2020- W1 and W2 sample not taken for January 02/02/2020- Emissions to Air refrigerant R404A. 02/02/20- S1 - Emission exceedance-SS 02/02/20- S1 - Emission exceedance- COD 02/01/20- S1 - Emission exceedance-Oils & Grease 01/12/19- Emissions to Air refrigerant-R448A

Name*	Thomas Caswell
Post	Technical Services and Environmental Manager
Signature	
Date	27/07/2022

Permit and introductory note: the PPC Regulations
Schedule 1 - Notification of abnormal emissions

* authorised to sign on behalf of Kepak Red Meat Division