

CONSENT VARIATION

RIVERS (CONTROL OF POLLUTION) ACTS 1951-1961

THE WATER AUTHORITIES (CONTROL OF DISCHARGES) ORDER 1978

I am directed by the Secretary of State for Wales to refer to the discharge consent in respect of the FRONCLYSVILLE.. sewage treatment works dated 17... OCTOBER... 1981.

The Secretary of State for Wales, having consulted with the Welsh Water Authority, hereby gives notice that in exercise of his powers under Articles 4(8) and 8 of the Water Authorities (Control of Discharges) Order 1978 (SI 1978 No 1210), the conditions imposed on the said consent shall be varied in the following terms:

CONDITIONS

The quality and quantity of effluent shall not exceed the following maximum values:

Biochemical Oxygen Demand (+ ATU) over 5 days at 20°C; 150 milligrammes per litre.

Suspended Solids dried at 105°C; 150 milligrams per litre.

Ammoniacal ammonia expressed as nitrogen 50 milligrams per litre.

Dry Weather Flow ~~litres per second~~ or 114 metres cubed per day.

Maximum rate of flow 4.41 litres per second
or 381 metres cubed per day.

This variation takes effect from the ..30.. January 1985.

This notice should be retained with the consent dated ..17... OCTOBER 1981.

George Roberts

WEP Division
Welsh Office