

**The Eels (England and Wales) Regulations 2009
Regulation 17(5)(a) and 23(2)**

EEL SCREEN EXEMPTION NOTICE

To: The Company Secretary
United Utilities Water Limited
Haweswater House
Lingley Mere Business Park
Lingley Green Avenue
Great Sankey
Warrington
WA5 3LP

Under Regulation 17(4) of the Eels (England and Wales) Regulations 2009, on or after 1 January 2015, a responsible person must ensure an eel screen is placed in a diversion structure that:

- (a) is capable of abstracting at least 20 cubic metres of water through any one point in any 24 hour period; or
- (b) returns water to a channel, bed or sea.

In accordance with Regulation 17(5) (a) of the Eels (England and Wales) Regulation 2009, this notice exempts you, as the responsible person, from the requirement to place an eel screen at:

The Shropshire Union Canal intake
The Horseshoe Falls
Llangollen
(NGR – SJ 19588 43283)

The reason for this exemption is:

That further time is needed to complete the design and go through the planning process. A further exemption will be considered when all tasks stated in the delivery plan for B23 (April 2023 to March 2024) are completed.

This exemption takes effect on 01/07/2023 and expires on 30/04/2024.

Date ...25/07/2023..... Signed 

Title... Denbighshire Environment Team Leader

The Natural Resources Body for Wales
Buckley office
Chester road
Buckley
Flintshire
CH7 3AJ