Permit Reference Number: BL3986ID

Operator: Tarmac Cement & Lime Ltd

Installation: Aberthaw Works

Form Number: Water 1 / 19/07/16

Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2 for the period 01/01/19 to 31/01/19

Emission Point	Parameter	Emission Limit Value	Result	Date of Measurement	Method
W1	pH (minimum)	6	**8.3**	**23.01.2019**	BS ISO10523
W1	pH (maximum)	9	-	-	BS ISO10523
W1	Total Suspended Solids (Maximum)	50 mg/l	**6.0 mg/l**	**23.01.2019**	BS EN 872
W1	Oil or Grease	None Present	**None Visible**	**23.01.2019**	Visual Check
W2	pH (minimum)	6	-	-	BS ISO10523
W2	pH (maximum)	9	-	-	BS ISO10523
W2	Total Suspended Solids (Maximum)	50 mg/l	-	-	BS EN 872
W2	Oil or Grease	None Present	-	-	Visual Check

Signed : K. Bennett **Date :26.04.2019**
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

Permit Reference Number: BL3986ID

Operator: Tarmac Cement & Lime Ltd

Installation: Aberthaw Works

Form Number: Water 1 / 19/07/16

Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2 for the period 01/02/19 to 28/02/19

Emission Point	Parameter	Emission Limit Value	Result	Date of Measurement	Method
W1	pH (minimum)	6	**8.2**	**19.02.2019**	BS ISO10523
W1	pH (maximum)	9	-	-	BS ISO10523
W1	Total Suspended Solids (Maximum)	50 mg/l	**30 mg/l**	**19.02.2019**	BS EN 872
W1	Oil or Grease	None Present	**None Visible**	**19.02.2019**	Visual Check
W2	pH (minimum)	6	-	-	BS ISO10523
W2	pH (maximum)	9	-	-	BS ISO10523
W2	Total Suspended Solids (Maximum)	50 mg/l	-	-	BS EN 872
W2	Oil or Grease	None Present	-	-	Visual Check

Signed : K. Bennett **Date :26.04.2019**
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

Permit Reference Number: BL3986ID

Operator: Tarmac Cement & Lime Ltd

Installation: Aberthaw Works

Form Number: Water 1 / 19/07/16

Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2 for the period 01/03/19 to 31/03/19

Emission Point	Parameter	Emission Limit Value	Result	Date of Measurement	Method
W1	pH (minimum)	6	**8.2**	**27.03.2019**	BS ISO10523
W1	pH (maximum)	9	-	-	BS ISO10523
W1	Total Suspended Solids (Maximum)	50 mg/l	**<5.0 mg/l**	**27.03.2019**	BS EN 872
W1	Oil or Grease	None Present	**None Visible**	**27.03.2019**	Visual Check
W2	pH (minimum)	6	-	-	BS ISO10523
W2	pH (maximum)	9	-	-	BS ISO10523
W2	Total Suspended Solids (Maximum)	50 mg/l	-	-	BS EN 872
W2	Oil or Grease	None Present	-	-	Visual Check

Signed : K. Bennett **Date :26.04.2019**
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)